

Facts

- 1. The City of Paso Robles has adopted a Climate Action Plan (CAP) in order to reduce greenhouse gas (GHG) emissions resulting from City government operations and community activities within Paso Roble and prepare for the anticipated effects of climate change. According to the City's GHG emissions inventory, the City government operations represents approximately four percent of Paso Robles' total community-wide GHG emissions. The City is committed to reducing its GHG emissions by 15 percent below 2005 levels by 2020, consistent with Assembly Bill (AB) 32.
- 2. Climate action plan Action Measure C-3 sets a target of installing 100 kW renewable energy systems on City property. The proposed project would quadruple this target with an estimated carbon reduction of 100 metric tons of CO2 equivalent greenhouse gas emissions.
- 3. The City of Paso Robles also desires to reduce the steadily rising costs of meeting the energy needs at its facilities.
- 4. On December 15, 2015, the City Council approved a Power Purchase Agreement with SunEdison LLC to authorize SunEdison to own, install and maintain solar installations at City properties at its own expense, without any upfront capital contribution from the City. The City Council made findings that the anticipated cost to the City for electrical energy provided by the Project will be less than the anticipated cost to the City using electricity provided by PG&E.
- 5. As part of the Power Purchase Agreement, both Centennial Park and Sherwood Park were identified as project sites.
- 6. Centennial Park is located at 600 Nickerson Drive, and Sherwood Park is located at 1860 Creston Road. Both parks are located in the R-1 (Residential Single Family) zoning district, see Attachments 1 and 3. (Vicinity Map).
- 7. Table 21.16.200 of the Zoning Ordinance requires a Conditional Use Permit (CUP) for public utilities facilities, which would include solar energy systems, in the R-1 zone.
- 8. For Centennial Park, the applicant proposes to install a 126 kilowatt photovoltaic system encompassing 8,300 square feet in size. The design of the system will be a solar canopy structure located along the center median of the parking lot, see Attachment 5 (Site Plan). The structure will be

erected over 45 parking spaces, two of which are accessible parking spaces. The structure will have a height range of 13 feet-6 inches to 20 feet-3 inches, and will have a tilt of 7 degrees. The canopy columns and supporting framework will consist of steel with concrete bollards at the base of the columns. All trees within the canopy area will be removed (seven trees total) as well as the existing light poles. New light fixtures will be installed underneath the canopy.

- 9. For Sherwood Park, the applicant proposes to install a 280 kilowatt photovoltaic system encompassing 18,742 square feet in size. The design of the system will be a solar canopy structure located along the center of the parking lot, see Attachment 6 (Site Plan). The structure will be erected over 54 parking spaces. The structure will have a height range of 13 feet-6 inches to 20 feet-3 inches and will have a tilt of seven degrees. The canopy columns and supporting framework will consist of steel with concrete bollards at the base of the columns. There are no trees or light fixtures located within the canopy area. New light fixtures will be installed underneath the canopy.
- 10. The Parks and Recreations Advisory Committee reviewed both projects at their meeting on April 11, 2016 and were supportive of both proposals.
- 11. The Development Review Committee (DRC) reviewed this project at their meeting on November 14, 2016. Since both projects are viewable from the public right-of-way, the DRC requested elevation renderings of each site be provided for the Planning Commission meeting, see Attachments 2a and 4a. (Photo Simulation).
- 12. Both applications are Categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA), per Section 21080.35 of the Public Resources Code.

Options

After consideration of any public testimony, the Planning Commission should consider the following options:

- 1. Approve the draft Resolution A and draft Resolution B approving the proposed Conditional Use Permits 16-004 and 16-005, subject to site specific conditions of approval;
- 2. Refer the item back to staff for additional analysis
- 3. Deny Conditional Use Permits 16-004 based on findings to be specified in the Planning Commission motion
- 4. Deny Conditional Use Permits 16-005 based on findings to be specified in the Planning Commission motion

Analysis and Conclusions

In 2013, the City of Paso Robles adopted a Climate Action Plan aimed at reducing greenhouse gas (GHG) emissions and preparing for the anticipated effects of climate change. According to the City's GHG emissions inventory taken in 2012, City government operations represents approximately four percent of Paso Robles' total community-wide GHG emissions. As part of the City's commitment to reducing its GHG emissions, the City Council previously approved a Power Purchase Agreement to SunEdison LLC to authorize SunEdison to own, install and maintain solar installations at both Centennial and Sherwood Parks. The solar energy that will be captured at each project site will provide energy back to its respective facilities and will cost less than the City using electricity provided by PG&E. For instance, the facilities at Centennial Park will consume its energy directly from the photovoltaic system in the parking lot. The

same would apply to Sherwood Park with the addition of its solar system also providing energy to the Veterans Memorial building.

In addition to reducing GHG emissions, the City also has the opportunity to achieve significant financial savings upon completion of the solar canopy project. Because SunEdison will own, install and maintain the solar installations at its own expense, without any upfront capital contribution from the City, the savings will commence as soon as the installations are complete and producing power.

The R-1 zone allows public utilities facilities with the approval of a CUP. The discretion authorized with the approval of a CUP gives the Planning Commission the ability to require specific conditions of approval to insure that a particular use is compatible with surrounding uses/residences.

Project Summary

For the Planning Commission to consider two separate Conditional Use Permits for the installation of a photovoltaic system canopy structure within the existing parking lots at Centennial Park and Sherwood Park.

- Centennial park 126 kilowatt photovoltaic system encompassing 8,300 square feet in size
- Sherwood Park 280 kilowatt photovoltaic system encompassing 18,742 square feet in size.

General Plan / Zoning Consistency

Both properties are designated in the General Plan Land Use Element as Parks and Open Space (POS) and are zoned Residential Single Family (R-1). The Zoning Ordinance allows for public utilities facilities in the R-1 zone, subject to a CUP.

Neighborhood Compatibility / Site Design Issues

The applicant has provided site plans showing the proposed locations of each solar canopy structure. The design of the canopies are typical for parking lots. Additionally, the applicant has addressed concerns of maneuverability of larger vehicles, such as RVs, by raising the canopy's minimum height to 13 feet-6 inches.

A condition of approval has been added that requires that all lighting to be downward directed and shielded to prevent offsite glare in conformance with section 21.21.040 of the City's Zoning Ordinance.

Architecture and Appearance

Both projects would be constructed in an existing parking lot. Due to the minimum requirements for height and size of the canopy structures, the existing landscaping at both parks will serve to minimize the changes in view-sheds at both sites. Both canopy structures will be framed with steel and will be painted a dark green to match existing park colors.

• The Centennial Park parking lot is surrounded by primarily single-family residences to the west but is setback nearly 100 feet from the street and oriented perpendicular to public views. The existing landscaping consists of large mature trees at the entrance to the parking lot from Nickerson Drive. The trees will help shield visibility from adjacent streets.



• The Sherwood Park parking lot is surrounded by a variety of uses including single-family residential to the north, multiple-family residential to the southwest, and a golf course directly west of the site. The canopy at Sherwood Park will be located parallel to the Creston Road frontage behind a tree-lined landscaping strip.



CEQA issues

Both applications are Categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA) per Section 21080.35 of the Public Resources Code.

Options

Option 1. Approval of both the Centennial Park and Sherwood Park projects is consistent with the City's climate action plan and previously approving a Power Purchase Agreement to SunEdison LLC to authorize SunEdison to own, install and maintain solar installations at both parks, subject to a Conditional Use Permit. Additionally, both projects will assist the City in reducing the steadily rising costs of meeting the energy needs at its facilities.

Option 2. Option 2 takes into account continuing the item to a future Planning Commission meeting to further review the projects' compatibility with surrounding neighborhoods. However, since the solar canopies have been designed specifically to be the most efficient in capturing solar energy, additional modifications to the project may reduce the projects' efficacy and may not coincide with the Power Purchase Agreement the City has entered into with the applicant.

Fiscal Impact

Significant savings in energy costs over the next twenty (20) years, totaling approximately \$1.3 million for both projects. No capital outlay by City required, as all of the solar equipment will be owned, installed and maintained by SunEdison.

Recommendation

Option 1. Approve draft Resolution A and draft Resolution B, approving the proposed Conditional Use Permits 16-004 and 16-005, subject to site specific conditions of approval;

Attachments

- 1. Vicinity Map, Centennial Park
- 2. Site Photos, Centennial Park
 - a. Photo Simulation, Centennial Park
- 3. Vicinity Map, Sherwood Park
- 4. Site Photos, Sherwood Park a. Photo Simulation, Sherwood Park
- 5. Site Plan, Centennial Park
- 6. Site Plan, Sherwood Park
- 7. Draft Resolution A CUP 16-004
- 8. Draft Resolution B CUP 16-005
- 9. Mail affidavit, Centennial Park
- 10. Mail affidavit, Sherwood Park
- 11. Newspaper affidavit

Attachment 1 Vicinity Map - Centennial Park



Attachment 2 Site Photos - Centennial Park



Photo #1: Looking southeast at the Centennial Park parking lot from Nickerson Drive.



Photo #2: Looking east towards the Centennial Park parking lot from Nickerson Drive.



Photo #3: Looking northeast towards the Centennial Park parking lot from Nickerson Drive.

Attachment 2a Photo Simulation - Centennial Park



Attachment 3 Vicinity Map - Sherwood Park



Attachment 4 Site Photos - Sherwood Park



Photo #1: Looking south at the Sherwood Park parking lot from Santa Ynez Avenue.



Photo #2: Looking southeast towards the Sherwood Park parking lot from Creston Road.



Photo #3: Looking east towards the Sherwood Park parking lot from Creston Road.



Photo #4: Looking northeast towards the Sherwood Park parking lot from Creston Road.

Attachment 4a Photo Simulation - Sherwood Park







Attachment 7 Draft Resolution A

RESOLUTION NO: 16-XXX

A RESOLUTION OF THE PLANNING COMMISSION OF THE CITY OF EL PASO DE ROBLES TO APPROVE CONDITIONAL USE PERMIT 16-004 CENTENNIAL PARK 600 Nickerson Drive (APN: 009-561-051)

WHEREAS, Table 21.16.200 of the Zoning Ordinance of the City of El Paso de Robles requires a Conditional Use Permit (CUP) for public utilities facilities in the R-1 zone; and

WHEREAS, the applicant, SunEdison LLC, has filed a Conditional Use Permit (CUP) application proposing to install a photovoltaic system canopy structure within the existing parking lot of Centennial Park located at 600 Nickerson Drive; and

WHEREAS, this application is Categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA) per Section 21080.35 of the Public Resources Code; and

WHEREAS, a duly noticed public hearing was conducted by the Planning Commission on December 13, 2016, to consider the facts as presented in the staff report prepared for this project, and to accept public testimony regarding this conditional use permit request; and

WHEREAS, based upon the facts and analysis presented in the staff report and public testimony received and subject to the conditions of approval listed below, the Planning Commission finds that the establishment, maintenance and operation for the requested use and building would be consistent with the General Plan and not be detrimental to the health, safety, morals, comfort, convenience and general welfare of the persons residing or working in the neighborhood of such proposed use, or be injurious or detrimental to property and improvements in the neighborhood or to the general welfare of the City.

NOW, THEREFORE, BE IT RESOLVED, that the Planning Commission of the City of El Paso de Robles does hereby approve Conditional Use Permit 16-004 subject to the following:

Section 1 - Findings: based upon the facts and analysis presented in the staff report, public testimony received and subject to the conditions listed below, the Planning Commission makes the following findings:

- 1. The proposed use is consistent with the General Plan and Zoning Ordinance; and
- 2. The proposed use satisfies the applicable provisions of the Zoning Ordinance; and
- 3. The establishment, and subsequent operation or conduct of the use will not, because of the circumstances and conditions applied in the particular case, be detrimental to the health, safety or welfare of the general public or persons residing or working in the neighborhood of the use, or be detrimental or injurious to property or improvements in the vicinity of the use; and

- 4. That the proposed project or use will not be inconsistent with the character of the immediate neighborhood or contrary to its orderly development; and
- 5. That the proposed use or project will not generate a volume of traffic beyond the safe capacity of all roads providing access to the project, either existing or to be improved in conjunction with the project, or beyond the normal traffic volume of the surrounding neighborhood; and

Section 2- Environmental Determination: This projects qualifies for as categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA) per Section 21080.35 of the Public Resources Code.

Section 3 - Approval: Conditional Use Permit 16-004 is approved subject to the following:

- 1. This Conditional Use Permit (CUP) authorizes the installation of a photovoltaic system canopy structure within the existing parking lot of Centennial Park located at 600 Nickerson Drive as shown in Exhibit B (Development Plans).
- 2. The project shall be constructed so as to substantially conform with the following listed exhibits established by this resolution:

EXHIBIT	DESCRIPTION
А	Project Conditions
В	Development Plans

PASSED AND ADOPTED THIS 13th day of DECEMBER, 2016 by the following Roll Call Vote:

AYES:

NOES:

ABSENT:

ABSTAIN:

BOB ROLLINS, CHAIRMAN

ATTEST:

WARREN FRACE, SECRETARY OF THE PLANNING COMMISSION

Exhibit A Exhibit B

Exhibit A

Conditions of Approval – CUP 16-004

Planning Division Conditions:

- 1. The project shall be constructed so as to substantially conform with Exhibit B (Development Plans).
- 2. Prior to issuance of the building permit, the applicant shall submit for review and approval the selected color sample, as determined by the Community Development Department, for the steel component of the canopy structure.
- 3. All lighting shall be downward directed and shielded to prevent offsite glare in conformance with Section 21.21.040 of the City's Zoning Ordinance.
- 4. Upon completion of the construction of the project, the public property and any improvements thereon shall be restored to a good and safe condition.
- 5. Any condition imposed by the Planning Commission in granting this Conditional Use Permit may be modified or eliminated, or new conditions may be added, provided that the Planning Commission shall first conduct a public hearing in the same manner as required for the granting of the original permit. No such modification shall be made unless the Commission finds that such modification is necessary to protect the public interest and/or neighboring properties, or, in the case of deletion of an existing condition, that such action is necessary to permit reasonable operation and use under the Conditional Use Permit.

Emergency Services Conditions:

- 6. All hazardous electrical transmission lines must be labeled "CAUTION Electrical Hazard".
- 7. Warning labels shall appear on the utility interactive inverter or be applied by the installer near the ground fault indicator at a visible location stating the following:
 - a. Warning Electrical Shock Hazard
- 8. Shut down and/or isolation procedures will be clearly displayed on the main electrical service panel exterior shunt trip device designed to terminate power to all electrical service (solar and domestic) when the main service disconnect is in the off position.
- 9. Main electrical service panel shall be labeled "Solar Power Enhanced"

4		0	4	Exhibit B - Deve	iopinent ria		
	Cur	Fdicon		SO ROBLÊS	Sun elevente al activity of the second secon		
	JUL	ILUISUII			E		
			600 NICKERSON DF	R. PASO ROBLES, CA			
			30% E	DESIGN	STAMP:		
		PROJECT LOCATION	CONTRACTOR OF SUBJECT AND ADDRESS TO SUBJECT TO SUBJECT AND ADDRESS AND UTILIZE ADDRESS AND ADDRESS AND UTILIZE ADDRESS AND ADDRESS A	GENERAL Sheet Rev. Sheet Title G-001 TITLE SHEET General NOTES G-002 GENERAL NOTES ARCHITECTURAL Sheet ARCHITECTURAL Sheet Title A-101 MASTER SITE PLAN A-201 A-201 ARCHITECTURAL RENDERINGS A-501 A-501 ACCESSIBILITY DETAILS ELECTRICAL Sheet Sheet Title Number Rev Sheet Title A-501 ACCESSIBILITY DETAILS Secondary Seco	CITY OF PASO ROBLES ENTENIAL PARK		
	and the second sec			E-300 EUDIPMENT CABELS AND DETAILS E-801 SPECIFICATION SHEET	с Ц Ю		
PROJECT DEVELOPER	SITE CONTACT	SCOPE OF WORK	APPLICABLE CODES AND STANDARDS	E-300 EUDIPMENT LABELS AND DE FAILS E-801 SPECIFICATION SHEET	C L B		
PROJECT DEVELOPER SUNEDISON 600 CLIPPER ORIVE BELMONT, CA, 54002 (600) 453-5600 PROJECT ENGINEER: ANTHONY FREIRA PH: 650-278-6593 PH	SITE CONTACT SUMEDISON 600 CLIPPER DRIVE BELMONT, CA, 54002 (650) 453-5600	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KV DC PATED PHOTOVOLTAIC SYSTEM AT 600 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET.	APPLICABLE CODES AND STANDARDS CALFORNA BUILDING CODE (GEC) 2013 EDITION CALFORNA ENERGY CODE 2013 CALFORNA ENERGY CODE 2013 EDITION CALFORNA ENERGY CODE 2013 EDITION CALFORNA ENERGY CODE 2013 EDITION CALFORNA ECHANICAL CODE 2013 EDITION CALFORNA ECHANICAL CODE 2013 EDITION CALFORNA ELECTRICAL CODE 2013 EDITION CALFORNA ELECCHICAL CODE 2013 COLFORNIA AMENDMENTS) 2013 CALFORNA ELECCED STANADAS, PART 12, TITLE 24, C.C.R.	E-300 EUUPMENT DABLS AND DE RALS E-801 SPECIFICATION SHEET	C LL B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: ARCH 'D'		
PROJECT DEVELOPER SUREDISON 000 CLIPPER DRIVE BELMONT, CA, 94002 (650) 453-5600 PROJECT ENSINEER: ANTHONY FEREIRA PH: 650-278-6583 PH: 650-278-6583 ARCHITECT ANTHONY FEREINA	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, 64, 94002 (650) 453-5600	SCOPE OF WORK This Design Package PROVIDES DRAWINGS FOR THE INSTALLATION OF A 126KW DF ARTEO PHOTOVOLTAIC SYSTEM AT 600 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA FIECTOCOE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA REFERENCED STANDARDS, PART 12, TITLE 24, C. C. R. TITLE 19 C. C. R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PARTIAL 1 LIST OF APPLICABLE STANDARDS-	E-306 EQUIPMENT LABELS AND DE LALS E-801 SPECIFICATION SHEET	C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: 24* X39* (610 x 914 52* 12* 12* 12* 12* 12* 12* 12* 12* 12* 1		
PROJECT DEVELOPER SUNEDISON 600 CLIPPER DRIVE BELMONT, CA, 94002 (660) 453-5600 PROJECT ENINEER: ANTHONY FEREIRA PH: 650-278-6593 (610) 453-4500 ACCHITECT (630) 453-4500 [cdfdess] (cdfdess] [cdfdess] (cdfdess] [cdfool] (cdfdess]	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5600 GEOTECHNICAL ENGINEER GEOTEK, INC. SUBERSTREAMED AVENUE #105	SCOPE OF WORK This Design Package PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KW DC RATED PHOTOVOLTAIC SYSTEM AT 600 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) SYSTEM SIZE ACCECT 12727000.	APPLICABLE CODES AND STANDARDS CALIFORNIA BUILDING CODE (CBC) 2013 EDITION CALIFORNIA FIRE CODE 2013 EDITION CALIFORNIA FIRE CODE 2013 EDITION CALIFORNIA FIRE CODE 2013 EDITION CALIFORNIA ENCHANICAL CODE 2013 EDITION CALIFORNIA BULCADIC CODE 2013 EDITION CALIFORNIA BULCADIC CODE 2013 EDITION CALIFORNIA BULCATICAL CODE 2013 EDITION CALIFORNIA FUNCTION PARTIAL LIST OF APPLICABLE STANDARDS: NIFPA 13 AUTOMATICS \$PIRINKLERS SYSTEM 2010 EDITION NIFPA 14 AUTOMATICS SPIRINKLERS SYSTEM 2010 EDITION NIFPA 17 DRY CHEMICAL EXTINGUISHING SYSTEMS 202 EDITION NIFPA 17 DRY CHEMICAL SYSTEMS 202 EDITION NIFPA 17 DRY CHEMICAL SYSTEMS 202 EDITION	E-306 EUDIPMENT LABELS AND DE LALS E-801 SPECIFICATION SHEET	C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: 24*X8 ^{CH} ^{TD} 24*X8 ^{CH} ^{TD} 15 15 15 15 15 15 15 15 15 15		
PROJECT DEVELOPER SUNEDISON 000 CLIPPER DRIVE BELMONT, CA, 94002 000 BROLEDER DRIVE 000 PROLECT ENGINEER: 000 ANTHONY FEREIRA 100 PH: 690-276-6633 000 GOURDANT FEREIRA 100 GOURDANT FEREIRA 100 GUIDANTONY 100 GUIDANTONY 100 GUIDANTONY 100 GUIDANTONY <t< td=""><td>SITE CONTACT SUMEDION 800 CLIPPER DRIVE BELMONT, CO. 94002 (650) 453-5600 BELMONS FRASER GEOTECHNICAL ENGINEER GEOTEK, NC GEOTEK, NC GEOTEK, NC CORONA, CA 92970 PHONE: (951) 710-1167</td><td>SCOPE OF WORK This design Package Provides DRAWINGS FOR THE INSTALLATION OF A 128kW DC RATED PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) DC STC (26.60 NW) SYSTEM SIZE (AC) (CEC) AC CE (11.747 NW)</td><td>APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA NERCHAYCOLE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL SUBJECTION COLEDRINA PERFERENCES STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PARTIAL LIST OF APPLICABLE STANDARDS. NFPA 14 STANDEPE SYSTEM 2007 EDITION NFPA 15 STANDARY PUNCHES 2016 EDITION NFPA 17 NET COME CLAN ACCENT FROME 2007 EDITION NFPA 20 TRIONARY PUNCH ENER 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION <</td><td>E-300 EUUPMENI DABLS AND DE IALS E-801 SPECIFICATION SHEET</td><td>C LL B PROJECT NUMBER: CA-15-1043 SHEET ITLE: TITLE SHEET SHEET SIZE: SHEET S</td></t<>	SITE CONTACT SUMEDION 800 CLIPPER DRIVE BELMONT, CO. 94002 (650) 453-5600 BELMONS FRASER GEOTECHNICAL ENGINEER GEOTEK, NC GEOTEK, NC GEOTEK, NC CORONA, CA 92970 PHONE: (951) 710-1167	SCOPE OF WORK This design Package Provides DRAWINGS FOR THE INSTALLATION OF A 128kW DC RATED PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) DC STC (26.60 NW) SYSTEM SIZE (AC) (CEC) AC CE (11.747 NW)	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA NERCHAYCOLE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL SUBJECTION COLEDRINA PERFERENCES STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PARTIAL LIST OF APPLICABLE STANDARDS. NFPA 14 STANDEPE SYSTEM 2007 EDITION NFPA 15 STANDARY PUNCHES 2016 EDITION NFPA 17 NET COME CLAN ACCENT FROME 2007 EDITION NFPA 20 TRIONARY PUNCH ENER 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION <	E-300 EUUPMENI DABLS AND DE IALS E-801 SPECIFICATION SHEET	C LL B PROJECT NUMBER: CA-15-1043 SHEET ITLE: TITLE SHEET SHEET SIZE: SHEET S		
PROJECT DEVELOPER SUNEDISON 000 CLIPPER DRIVE BELMONT, CA, 94002 000 BOLGOT ENGINEER: 000 ATTHONY FEREIRA PH: 650-278-6593 ARCHITECT [address] [address] [address] [address] [phone] [address] [phone] [address] [phone] LICENSED ARCHITECT: CA REGAG CA REGAG CAREGAG	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, CA, 94002 (650) 453-5600 GEOTECHNICAL ENGINEER GEOTEK, NC: 710 EAST PARKRIDGE AVENUE, #105 CORONA, CA 92979 PHONE: (651) 710-1167 LLC, #CEG 2381 EXP. 930177	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KV DC AATED PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 9346. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) DC STC 22830 W SYSTEM SIZE (DC) AC CE 113.747 W INVERCENT (2) SUNGROW SG60KU-M PV INVEREES INVERTER (2) SUNGROW SG60KU-M PV INVEREES	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY ENERGY STATE TRE MARSHAL REGULATIONS PRTILL LISTO F APPLICABLE STANDARDS NTPA 13 VITOMATIC SPRINKERS SYSTEM 2010 EDITION NFPA 13 STANDPIPE SYSTEM 2002 EDITION NFPA 14 STANDPIPE SYSTEM 2002 EDITION NFPA 15 TOTIONARY EOR SYSTEMS 2002 EDITION NFPA 20 REVINING SYSTEMS 2002 EDITION NFPA 21 REVINATE INTE AXIN SUDI EDITION NFPA 22 REVINATE NEE EXTINGUISHING SYSTEMS 2002 EDITION NFPA 24 REVINATE INTE EXTINGUISHING SYSTEMS 2003 EDITION NFPA 24 REVINATE REXTINGUISHING SYSTEMS 2003	E-300 EUUPMENI DABLS AND DE IALS E-801 SPECIFICATION SHEET	C LL C PROJECT NUMBER: CA-15-1043 SHEET TITLE TITLE SHEET SHEET SIZE: ARCH TD 24* X39* (610 x 91 24* X39* (610 x 91 CHE SHORE WITHOU TO BE USED ON Y 91 CONNECTION TO BE USED ON Y 91 CONNECTION DISCUSSED TO THE SHORE WITHOU PERMISSION FROM SINCESON LLC NO. REVISION 1 MODULE 10-1 2 CITY COMMENTS 11-0		
PROJECT DEVELOPER SUNEDISON 600 900 CLIPPER DRIVE 600 801 MEDISON 600 900 CLIPPER DRIVE 600 801 MEDISON 600 900 SLIPPER DRIVE 600 ANTHONY FEREIRA PH: 650-278-6593 ACCHATECT [address] [address] [address] [address] [address] [address] [company name] [address] [company name] <tr< td=""><td>SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, KG, 94002 (650) 453-5600 GEOTECHNICAL BENGERER GEOTEK, INC. TUBENT PAGE2005 FUENT: AGREER GEOTEK, INC. TUBENT PAGE2005 FUENT: GEOTEK, INC. TUBENT PAGE2005 FUENT: GEOTEK, INC. TUBENT: GEOTEK</td><td>SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 1600 ES, CALED PHOTOVOLTAIC SYSTEM AT 600 NICKERSON DR, PASO ROBLES, CALEFORNIA, CAS SAMG. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) SYSTEM SIZE (DC) SYSTEM SIZE (DC) INVERTER INVERTER PV MODULE (CEC) 100 C STC (26.80 MV) INVERTER INVERTER PV MODULE OUNGROW SG60KU-M PV INVERERS PV MODULE</td><td>ALFORNIA BUILDING CODE (GC) 2013 EDITION CALFORNIA BUILDING CODE (GC) 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA PLUMBING CODE 2013 EDITION CALFORNIA PLUMBING CODE 2013 EDITION CALFORNIA FREE CODE AND 2010 CALFORNIA AMENDMENTS) CALFORNIA FREE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FREE CODE FANDADROS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FREE MARSHAL REGULATIONS PATTAL LIST OF APPLICABLE SYSTEM 2010 EDITION NFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2002 EDITION NFPA 15 AND AMENGAL SYSTEMS 2002 EDITION NFPA 15 AND AMENGAL SYSTEMS 2002 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION REFERENCE CODE SECTION FOR NFPA STANDARDS 1. THIS PROJECT SHOLD COMPLY WITH THE 2013 EDITION OF THE CALFORNIA BUILDING CODE (TITLE 24, WHICH ADOPTS THE 2012 BC</td><td>E-300 EUUPMENI LABELS AND DE IALES E-801 SPECIFICATION SHEET</td><td>C LL CALLS CONTRACT NUMBER: CAL15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: 24* 236*(610 stat 5***********************************</td></tr<>	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, KG, 94002 (650) 453-5600 GEOTECHNICAL BENGERER GEOTEK, INC. TUBENT PAGE2005 FUENT: AGREER GEOTEK, INC. TUBENT PAGE2005 FUENT: GEOTEK, INC. TUBENT PAGE2005 FUENT: GEOTEK, INC. TUBENT: GEOTEK	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 1600 ES, CALED PHOTOVOLTAIC SYSTEM AT 600 NICKERSON DR, PASO ROBLES, CALEFORNIA, CAS SAMG. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) SYSTEM SIZE (DC) SYSTEM SIZE (DC) INVERTER INVERTER PV MODULE (CEC) 100 C STC (26.80 MV) INVERTER INVERTER PV MODULE OUNGROW SG60KU-M PV INVERERS PV MODULE	ALFORNIA BUILDING CODE (GC) 2013 EDITION CALFORNIA BUILDING CODE (GC) 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA FREE CODE 2013 EDITION CALFORNIA PLUMBING CODE 2013 EDITION CALFORNIA PLUMBING CODE 2013 EDITION CALFORNIA FREE CODE AND 2010 CALFORNIA AMENDMENTS) CALFORNIA FREE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FREE CODE FANDADROS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FREE MARSHAL REGULATIONS PATTAL LIST OF APPLICABLE SYSTEM 2010 EDITION NFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2002 EDITION NFPA 15 AND AMENGAL SYSTEMS 2002 EDITION NFPA 15 AND AMENGAL SYSTEMS 2002 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION REFERENCE CODE SECTION FOR NFPA STANDARDS 1. THIS PROJECT SHOLD COMPLY WITH THE 2013 EDITION OF THE CALFORNIA BUILDING CODE (TITLE 24, WHICH ADOPTS THE 2012 BC	E-300 EUUPMENI LABELS AND DE IALES E-801 SPECIFICATION SHEET	C LL CALLS CONTRACT NUMBER: CAL15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: 24* 236*(610 stat 5***********************************		
PROJECT DEVELOPER SUNEDISON 000 CLIPPER DRIVE BELMONT, CA, 94002 000 000 CLIPPER DRIVE 000 PROJECT ENINEER: 000 ANTHONY FEREIRA 000 PH: 600-278-6030 000 ARCHITECT (address) [company name] (address) [company name] (address) [company name] (address) EXPIRATION: XXXXXXXXXXX STRUCTURE LENGINEER Company name] (address) address prod	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5600 GEOTECHNICAL ENGINEER GEOTEK, NC TID EAST PRAREIDCE AVENUE, #105 CORONA, CA 92870 PHONE: (691) 710-1167 LIC: #CE C3 2381 EXP: 93017 ELCROCE 3281 EXP: 93017	SCOPE OF WORK This besicin Package provides drawings for the installation of a range photocol taic system at 800 nickerson dr. paso a roble is, cultornia, cos sava. Environmental plans are not part of the scope of this plan set. PROJECT DESCRIPTION System size (DC) D c Std (28.80 W) System size (DC) INVERTER (PV MODULE (378) SUNGROW SG60KU-M PV INVERERS PV MODULE (379) SUNGROW SG60KU-M PV INVERERS PV MODULE (378) SUNGROW SG60KU-M PV INVERERS MONO -chistalLinePV MODULE	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 CALFORNIA ENERGY CODE 2013 CALFORNIA ENERGY CODE 2013 CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA MECHANICAL CODE 2013 EDITION CALFORNIA MECHANICAL CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA FIEC CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIEC CODE AND 2010 CALFORNIA AMENDMENTS) TAUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2007 EDITION NFPA 20 STATIONARY PUMPS 2007 EDITION NFPA 20 STATIONARY PUMPS 2007 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2010 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2010 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2012 EDITION NFPA 2011 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2012 EDITION NFPA 2011 CLEAN AGENT FIRE 2011 EDITION NFPA 2012 EDITION FIRE 2011 EDITION NFPA 2011 CLEAN AGE		C LL B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: 24*X8°(610×614 5-10×614 24*X8°(610×614 5-10×614 1-10×61		
PROJECT DEVELOPER SUNEDISON 600 CLIPPER DRIVE BELMONT, CA, 94002 (650) 453-5600 PROJECT ENGINEER: ANTHONY FEREIRA PH: 680-278-6933 ARCHITECT [company name] [address] [condison of the second of the second company name] [address] STRUCTURAL ENGINEER [company name] [address] [company name] [address] [company name] [address] [company name]	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5000 GEOTECHNICAL ENGINEER GEOTEK, NC: 710 EAST PARKIDGE AVENUE, #105 CORONA, CA 92870 PHONE: (650) 110-1167 LLC, # CEG 2381 EXP: 93017 ELCMELAL ENGINEER [Dompany name] [address] [pho] [phone]	SCOPE OF WORK This design package provides drawings for the installation of a 128kW do rated photovoltaic system at 800 nickerson dr. paso robust packages. PROJECT DESCRIPTION System size (dc) D c stc (26.80 W) System size (dc) (a) Sungrow Sceoku-M pv Inverers INVERTER Product area O strc (26.80 W) A Ce (113.747 W) Inverter (a) SUNGROW SG60KU-M pv Inverers PV MODULE MONO-cristal Line pv Mobdte TRANSFORMER N/A PROJECT AREA 8 300 SQ.F. Lattrue	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA FIERE CODE, PART 9. TITLE 24 C.C.R. TITLE 19 C.C.R. PUBLICASETY, STATE FIRE MARSHAL REGULATIONS PARTIAL LIST OF APPLICABLE STANDARDS PART TITLE 19 C.C.R. PUBLICASETY, STATE FIRE MARSHAL REGULATIONS NFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 14 STANDHIPE SYSTEM 2007 EDITION NFPA 15 AUTOMATIC SPRINKLERS SYSTEM 2010 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2020 EDITION NEFACODE SCITION FOR NFPA STANDARDS 1. THIS FROJECT SHOLLO COMPLY WITH THE 2013 EDITION OF THE CALFORNIA BALLEDING CODE (TITLE 24) WHICH ADOPTS THE 2012 IBC CALFORNIA BALLATA ADOPTERES 35, AMB 2012 IDC C		C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: SHEET SIZE: 24*X30*600 X940 C X X30*600 X9400 C X X30*600 X		
PROJECT DEVELOPER SUNEDISON 000 BOCLIPPER DRIVE 000 BELMONT, CA, 94002 000 PROJECT ENGINEER: 000 ANTHONY FEREIRA 000 PROJECT ENGINEER: 000 (address) 000 DELMONT FEREIRA 000 (address) 000 LICENSED ARCHITECT: 000 CA REGØ EXPIRATION: XXXXXXXXX STRUCTURAL ENGINEER: 000000000000000000000000000000000000	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5000 GEOTECHNICAL ENGINEER GEOTEK, INC. 710 EAST PARKIDGE AVENUE, #105 CORONA, CA 92879 PHODE: (651) 110-1167 LUC; # CEG 2381 EXP: 930017 ELECTRICAL ENGINEER [company name] [address] [chy] [stata] [chp] [phone] PROJECT ENGINEER: CA PE REGE C	SCOPE OF WORK. This design Package Provides DRAWINGS FOR THE INSTALLATION OF A 128kW DC PATED PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) DC STC (28.80 NY) SYSTEM SIZE (DC) NVROWER SIZE (DC) DC STC (28.80 NY) AC CEC (113.747 NY) SYSTEM SIZE (DC) DC STC (28.80 NY) AC CEC (113.747 NY) <td <="" colspan="2" td=""><td>APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENCRYCODE 2013 EDITION CALFORNIA ENCRYCHTOR SYSTEMS 2005 EDITION 1013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE TANDOLES SYSTEMS 2002 EDITION NFPA 12 STANDOPRE SYSTEM 2007 EDITION NFPA 13 STANDOPRE SYSTEM 2007 EDITION NFPA 14 STANDARY PUNKES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 DRIVENES 2007 EDITION NFPA 24 PRIVATE FIRE EXTINUCIPHING SYSTEMS 2008 EDITION NFPA 25 CALFORNIA HEALTHORE CODE STANDARDS 1 THIS PROJECT SHOULD COMERY WITH THE 2013 EDITION OF THE</td><td></td><td>C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE TITLE SHEET SHEET SIZE: SHEET SI</td></td>	<td>APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENCRYCODE 2013 EDITION CALFORNIA ENCRYCHTOR SYSTEMS 2005 EDITION 1013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE TANDOLES SYSTEMS 2002 EDITION NFPA 12 STANDOPRE SYSTEM 2007 EDITION NFPA 13 STANDOPRE SYSTEM 2007 EDITION NFPA 14 STANDARY PUNKES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 DRIVENES 2007 EDITION NFPA 24 PRIVATE FIRE EXTINUCIPHING SYSTEMS 2008 EDITION NFPA 25 CALFORNIA HEALTHORE CODE STANDARDS 1 THIS PROJECT SHOULD COMERY WITH THE 2013 EDITION OF THE</td> <td></td> <td>C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE TITLE SHEET SHEET SIZE: SHEET SI</td>		APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENCRYCODE 2013 EDITION CALFORNIA ENCRYCHTOR SYSTEMS 2005 EDITION 1013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE CODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FIERE TANDOLES SYSTEMS 2002 EDITION NFPA 12 STANDOPRE SYSTEM 2007 EDITION NFPA 13 STANDOPRE SYSTEM 2007 EDITION NFPA 14 STANDARY PUNKES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 DRIVENES 2007 EDITION NFPA 24 PRIVATE FIRE EXTINUCIPHING SYSTEMS 2008 EDITION NFPA 25 CALFORNIA HEALTHORE CODE STANDARDS 1 THIS PROJECT SHOULD COMERY WITH THE 2013 EDITION OF THE		C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE TITLE SHEET SHEET SIZE: SHEET SI
PROJECT DEVELOPER SUNEDISON 000 CLIPPER DRIVE BELMONT, CA, 94002 000 BOLDET DRIVE 000 PROJECT ENGINEER: 000 ANTHONY FEREIRA 000 PROJECT ENGINEER: 000 (address) 000 (phone) 000 (address) 000	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Co, 94002 (650) 453-500 GEOTECHNICAL ENGINEER GEOTEC, INC. 710 EAST PARKIDGE AVENUE, #105 CORONA, CA 92879 PHONE: (651) 710-1167 LIC, # CEG 2381 EXP: 93017 ELECTRICAL ENGINEER [company name] [address] [chy] [stata] [chp] [phone] PROJECT ENGINEER: CA PER REG & C EXPIRATION: soloutoxox	SCOPE OF WORK This DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KV DC PATED PHOTOVOLTAC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 93446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) DC STC (28.80 W) SYSTEM SIZE (DC) NVRCNMERTIAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. NYRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. SYSTEM SIZE (DC) OC STC (28.80 W) SYSTEM SIZE (DC) (AC CEE (113.747 W) AC CEE (113.747 W) AC CEE (113.747 W) NVERTER (J'9) SUNGROW SG60KU-M PV INVEREERS PV MODULE MONO-CRISTALINE PV MODULE TRANSFORMER NA PROJECT AREA B 300 SQ.F. LATITUDE SEA224' N120,8707' W AZMUTH 188° TIT TIT	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA FELCHORE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FERE FROET RECODE AND 2010 CALFORNIA AMENDMENTS) 2013 CALFORNIA FERE FROET RECODE STANDARDS, PART 12, TITLE 24, C. C. R. TITLE 19 C. C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PARTIAL LIST OF APPLICASLE STANDARDS NFPA 14 STANDPIPE SYSTEM 2007 EDITION NFPA 15 STANDPIPE SYSTEM 2007 EDITION NFPA 14 STANDARY DURING SOTE DITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 STATIONARY DURING SOTE DITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 CLAIF ORNIA HEALTH AND SAFETY CODE 1 THIS PROJECT SHOULD COMPLY WITH THE 2013 EDITION OF THE CALFORNIA BUILDING CODE (TITLE 2914 WICH ADOREST THE 2012 IBIC 2012 COC ARTICLE		C L B PROJECT NUMBER: CA-15-1043 SHEET ITLE: TITLE SHEET SHEET SIZE: SHEET SIZE: 24* 39* (610, 914) THE BARWING IT IN ROMETING LICE THIS INFORMATION SCONFECTION DE USED OKLY IN CONFECTION DE USED OKLY IN CONFECTION		
PROJECT DEVELOPER SUNEDISON 600 CLIPPER DRIVE BELMONT, CA, 94002 (60) 453-500 PROJECT ENGINEER: ANTHONY FEREIRA PROJECT ENGINEER: Company name] [address] [address] [city] [state] [zp] [phone] EXPLOSED ABCHITECT: CA: REC# EXPLATION: XXXXXXXXX STRUCTURAL ENGINEER: [city] [state] [zp] [phone] PROJECT ENGINEER: CA: PE C# C# EXPLATION: XXXXXXXXX	SITE CONTACT SUNEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5600 GEOTECHNICAL ENGINEER GEOTEC, INC. GLENS FRASER GEOTEK, INC. GLENS FRASER GEOTEK, INC. GLENS 42379 PHONE: (651) 710-1167 LIC # CE 2231 EXP: 913017 ELECTRICAL ENGINEER: [company name] [address] [ch] [state] [zp] [phone] PROJECT ENGINEER: CA PE REGA C EXPIRATION: action/cons	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KW DC RATEO PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 9346. ENVIRONMENTIAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. PROJECT DESCRIPTION SYSTEM SIZE (DC) OC STO 22830 WW AC CE 113.47 KW AC CE 113.47	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA FIRE CODE 2013 EDITION CALFORNIA ENCHAPCY CODE 2013 EDITION CALFORNIA ENCHAPCO (CODE 2013 EDITION CALFORNIA ENCHAPCO (CODE 2013 EDITION CALFORNIA ENCHAPCIA (CODE 2013 EDITION CALFORNIA ENCHAPCIA (CODE 2013 EDITION CALFORNIA ENCHAPCIA (CODE 2013 EDITION CALFORNIA ELECATORICA (CODE 2013 EDITION CALFORNIA ELECATORICA (CODE 2013 EDITION CALFORNIA ELECATORICA (CODE 2013 EDITION CALFORNIA ELECATORICED STANDARDS, PART 12, TITLE 24, C.C.R. 2013 CALFORNIA ELECATORICED STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PRATA MUTAMITIC SFIRMALERS SYSTEM 2010 EDITION NFPA 13 STANDPIPE SYSTEM 2007 EDITION NFPA 14 STANDPIPE SYSTEM 2002 EDITION NFPA 23 PRIVATE FIRE MAINS 2010 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 CLAIFORNIA BLILDING CODE (TITLE 24) WITH THE 2013 EDITION OF THE CALFORNIA BLILLDING CODE (TITLE 24) WITH ADDET ED12 BIT 1 THIS PROJECT SHOULD COMPLY WITH THE 2015 EDITION OF THE CALFORNIA BLILLDING CODU		C L G PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: SHEET S		
PROJECT DEVELOPER SUNEDISON SOUCLIPPER DRIVE BELMONT, CA, 94002 GEO, JASS-300 PROJECT ENGINEER: ANTHONY FERERA PH: 650-278-6593 ARCHITECT [address] [address] [address] [address]<	SITE CONTACT SUMEDISON 600 CLIPPER DRIVE BELMONT, Ca, 94002 (650) 453-5600 GEOTECHNICAL ENGINEER GEOTEK, INC. GLENIS FRASER GEOTEK, INC. GLENIS FRASER GEOTEK, INC. GLENIS FRASER GEOTEK, INC. TIDEAST PARKINGE AVENUE, #105 CONTAK, CA3293 LIC, #CCE 2381 EXP: 9/30/17 ELECTRICAL ENGINEER [company name] [address] [chi] [stato] [zp] [phone] PROJECT ENGINEER: CONTRACTOR CONTRACTOR CONTRACTOR [company name] [address] [chi] [stato] [zp] [phone]	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 128KV DC ANTED PHOTOVOLTAIC SYSTEM AT 800 NICKERSON DR, PASO ROBLES, CALIFORNIA CA 58446. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. WIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET. SYSTEM SIZE (DC) SYSTEM SIZE (DC) CC ET(228.00 W) SYSTEM SIZE (DC) CC ET(13.47 W) SYSTEM SIZE (DC) OC STG(28.00 W) SYSTEM SIZE (DC) NOT COLSPAN (SCORD W) SECON (SCORD-M) VIENTERS PV MODULE NA POLICT AREA 8 300 SQ.F. <td cols<="" td=""><td>APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA ELECATORICAL CODE 2013 EDITION CALFORNIA ELECATORICAL STATE TRE MARSHAL REGULATIONS PMETIAL LETORINA ENERGY ENTRE AC C.R. 2013 CALFORNIA ELECATICED STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PMETIAL LINGTONIA FIRE CODE AND 2010 EDITION NFPA 13 AUTOMATIC SPIRAULERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2007 EDITION NFPA 25 TATIONARY PUMPES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 TATIONARY PUMPE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSUSHING SYSTEMS 2008 EDITION <td< td=""><td>E-300 EUUPMENT LABELS AND DE LALES E-801 SPECIFICATION SHEET</td><td>C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: APPROVED BY: DRAWN BY: ENSINEER: APPROVED BY: PROJECT NUMBER: SHEET SIZE: PROJECT NUMBER: APPROVED BY: [scale]</td></td<></td></td>	<td>APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA ELECATORICAL CODE 2013 EDITION CALFORNIA ELECATORICAL STATE TRE MARSHAL REGULATIONS PMETIAL LETORINA ENERGY ENTRE AC C.R. 2013 CALFORNIA ELECATICED STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PMETIAL LINGTONIA FIRE CODE AND 2010 EDITION NFPA 13 AUTOMATIC SPIRAULERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2007 EDITION NFPA 25 TATIONARY PUMPES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 TATIONARY PUMPE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSUSHING SYSTEMS 2008 EDITION <td< td=""><td>E-300 EUUPMENT LABELS AND DE LALES E-801 SPECIFICATION SHEET</td><td>C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: APPROVED BY: DRAWN BY: ENSINEER: APPROVED BY: PROJECT NUMBER: SHEET SIZE: PROJECT NUMBER: APPROVED BY: [scale]</td></td<></td>	APPLICABLE CODES AND STANDARDS CALFORNIA BUILDING CODE (CBC) 2013 EDITION CALFORNIA ENERGY CODE 2013 EDITION CALFORNIA ELECTRICAL CODE 2013 EDITION CALFORNIA ELECATORICAL CODE 2013 EDITION CALFORNIA ELECATORICAL STATE TRE MARSHAL REGULATIONS PMETIAL LETORINA ENERGY ENTRE AC C.R. 2013 CALFORNIA ELECATICED STANDARDS, PART 12, TITLE 24, C.C.R. TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PMETIAL LINGTONIA FIRE CODE AND 2010 EDITION NFPA 13 AUTOMATIC SPIRAULERS SYSTEM 2010 EDITION NFPA 14 STANDPIPE SYSTEM 2007 EDITION NFPA 25 TATIONARY PUMPES 2007 EDITION NFPA 24 PRIVATE FIRE MAINS 2010 EDITION NFPA 25 TATIONARY PUMPE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSISHING SYSTEMS 2008 EDITION NFPA 201 CLEAN AGONT FIRE EXTINUSUSHING SYSTEMS 2008 EDITION <td< td=""><td>E-300 EUUPMENT LABELS AND DE LALES E-801 SPECIFICATION SHEET</td><td>C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: APPROVED BY: DRAWN BY: ENSINEER: APPROVED BY: PROJECT NUMBER: SHEET SIZE: PROJECT NUMBER: APPROVED BY: [scale]</td></td<>	E-300 EUUPMENT LABELS AND DE LALES E-801 SPECIFICATION SHEET	C L B PROJECT NUMBER: CA-15-1043 SHEET TITLE: TITLE SHEET SHEET SIZE: APPROVED BY: DRAWN BY: ENSINEER: APPROVED BY: PROJECT NUMBER: SHEET SIZE: PROJECT NUMBER: APPROVED BY: [scale]	





Exhibit B - Development Plans

Agenda Item 2

∕Box

c:\Users\dmeyer Renderings.dwg

Exhibit B - Development Plans

	1	2 3	4	5 6	
	ELECTRICAL NOTES FOR NEW PHOTOVOLTAIC SYSTEM:	23. USE MEYERSIOR APPROVED EQUIPMENT) HUB LISTED TO PROVIDE MOISTURE PROTECTION FOR CONDUIT ENTRANCES IN ALL APPLICABLE LOCATIONS AS REQUIRED BY NEC 314.15.	DISCONNECTING MEANS:	GENERAL NOTES FOR GRID TIE PHOTOVOLTAIC INVERTERS:	SunEdison
	THIS PROPOSED SOLAR ELECTRIC SYSTEM IS NOTENDED TO OPERATE IN PARALLEL WITH POWER RECEIVED FROM THE UTILITY SERVICE PROVIDER. THE INVERTER FOR THE PROPOSED SOLAR ELECTRIC SYSTEM SHALL BE IDENTIFIED FOR USE IN SOLAR	 PROTECT WIRE FROM SIMRP EDGES WITH UV RATED SPIRAL WRAP, EDGE-CURED, OR SPIT LOOM. MODILE EAD CONNECTORS SHALL BE INSTALLED SUCH THAT THEY ARE EASILY ACCESSIBLE AND PROTECTED FROM EXPOSURE TO DIRECT SULLIGHT OR RAN. THEY SHALL NOT BE INSTALLED WITHIN 	PHOLOGOLIAL OPARE SOURCE FROM ALL DIFFERENTIAL COMBLETIONS. 9. WHERE A CRECUTO FROMMON CONNECTION IS NOT DESEARCH TO BE ALTOMATICALLY INTERRIPTED AS PART OF THE GROUND FAULT PROTECTION SYSTEM REQUIRED BY NEC 400.5 A SWITCH OR CIRCUIT BREARER USED AS A DISCONFECTIVA GUENA SIALL NOT HAVE A POLE IN THE GROUNDED CONDUCTOR.	1. REFER TO EQUIPMENT INSTALLATION MANUAL.	60, 2015 SUNFERSON, LIC AND ITS AFFLATER, ALL ROUTS RESERVED 600 CLIPPER DRIVE BELMONT, CA 94002
	 PHOTOVOLTAC SYSTEMS. ALL EQUIPMENT SHALL BE UL APPROVED. THIS SYSTEM IS INTERDED TO CONNECT TO THE EXISTING FACILITY POWER SYSTEM AT A SINGLE POINT, POINT OF COMMON COUPLING (POCC). THIS CONNECTION SHALL BE IN COMPLIANCE WITH THE NEC 	TO BRAY, CONCUT OR INDUCE UP3. 1. THE STRING SOURCE CENTURY BRAY REPORT TO BE SUPPORTED ADEQUATELY IN LENGTHS NOT TO EXCEED 24. THE MODULE TO MODILE DATERCONNECTION LEADS NEED TO BE SUPPORTED AT A MINIMUM OF 12 FRAVITIEL FOR AND THE MODULE TO MODULE CONNECTION POINT.	THE GROINNED CONDUCTOR MAY HAVE A BOLTED OR TERMINAL DISCONNECTING MEANS TO ALLOW MAINTENANCE OR TROUBLESHOOTING BY QUALIFIED PERSONNEL. UNLESS DISCONNECTS SERVICING A LINE SIDE TAP, THE DISCONNECTING MEANS SHALL NOT BE		(650) 453-5600 www.sunedison.com
<text></text>	ARTICLE 705.12 "POINT OF CONNECTION." 4. ALL SOURCE CIRCUITS SHALL HAVE INDIVIDUAL SOURCE CIRCUIT PROTECTION FOR TESTING AND	27. POLARIS TAPS AND BLOCKS ARE NOT TO BE USED TO CONNECT CURRENT CARRYING CONDUCTORS.	REQUIRED TO BE SUITABLE AS SERVICE EQUIPMENT AND SHALL BE RATED IN ACCORDANCE WITH NEC 690.17.		
 A. S. A. S	5. ALL DISCONNECTING COMBINERS SHALL BE SECURED FROM UNAUTHORIZED/UNQUALIFIED PERSONNEL BYLLOGY OD LOCATION.	 MODULE TO SOURCE CIRCUIT CONNECTORS MUST BE OF THE SAME MAKE AND MODEL AS THE MODULE TO MODULE CONNECTORS. THE CONNECTION TO SOURCE CIRCUITS MUST BE PER THE MODULE MANUFACTURER AND CONNECTOR MANUFACTURER INSTRUCTIONS. CONTRACTOR TO VERIFY THAT THE 	 EQUIPMENT SUCH AS PHOTOVOLTAIC SOURCE CIRCUITS, OVER CURRENT DEVICES, AND BLOCKING DIODES SHALL BE PERMITTED ON THE PHOTOVOLTAIC SIDE OF THE PHOTOVOLTAIC DISCONNECTING MEANS. 		
<section-header> I. Solution of the second seco</section-header>	EXAMPLE ON DEALERN EVALUATION EVALUATI	STRING CONDUCTOR DIAMETER IS COMPATIBLE WITH THE STRING CIRCUIT HOME RUN CONNECTORS 29. HOMERUN STRING WIRING TO BE SUPPORTED IN INTERVALS NOT TO EXCEED 3' AND WITHIN 12' OF ALL	 MEANS SHALL BE PROVIDED TO DISCONNECT EQUIPMENT SUCH AS INVERTERS, BATTERIES, CHARGE CONTROLLERS, AND THE LIKE FROM ALL UNGROUNDED CONDUCTORS OF ALL SOURCES. IF THE CONTROLLERS AND THE DEPENDENT OF A DEPENDENT OF A DEPENDENT OF THE DEPENDENT OF A D		
<section-header> Martin Sampania Sampania</section-header>	7. EQUIPMENT SHALL BE INSTALLED IN A SECURE AREA.	TERMINATIONS. 30. PV WIRE HARDESSES SHALL NOT BE USED. CONDUCTORS SHALL BE PARALLELED AT COMBINER BOXES CONDUCTORS SHALL BE PARALLED AT COMBINER BOXES CONDUCTORS SHALL BE PARALLED AT COMBINER BOXES CONDUCTORS SHALL BE PARALLELED AT COMBINER BOXES CONDUCTORS SHALL BE PARALLED AT COMBINER BOXES CONDUCTORS SHALLED AT COMBINER BOXES CONDUCTORS S	EQUERMENT IS ENERGIZED FROM MORE THAN ONE SOURCE, THE DISCONNECTING MEANS SHALL BE GROUPED AND IDENTIFIED. 7. A SINCLE DISCONDUCTING MEANS SHALL BE DEPARTTED FOR THE COMBINED AC OUTDUT OF ONE OP		STAMP:
<text></text>	 CONDUTS AND CABLES SHALL NOT ENTER THE TOP OR SIDES OF ANY OUTDOOR ENCLOSURE ABOVE ELECTRIC/ELECTRONIC EQUIPMENT WITHOUT WRITTEN APPROVAL FROM SUNEDISON PROJECT ENGINEER. 	OR STRING INVERTIESS ONLY. 31. ALL EMT SHALL USE LISTED AND APPROVED RAIN TIGHT FITTINGS WHEN INSTALLED OUTDOORS OR IN A WEET LOCATION.	 A SINGLE WERCONNECTING MEENS SHALL BE FEMALTIED FOR THE COMBINED AC OUTFOL OF ONE OR MORE INVERTIGES IN AN INTERACTIVE SYSTEM, PROVIDED EACH INVERTER ASSOCIATED WITH THE DISCONNECT HAS ITS OWN INTERNAL AC DISCONNECT. 		
<section-header> Numerican <</section-header>	9. ALL METALLIC EXPANSION FITTINGS SHALL HAVE INTERNAL OR EXTERNAL BONDING TO ENSURE CONTINUITY.	32. OUTDOOR ELECTRICAL CONNECTIONS SHALL BE STAINLESS STEEL HARDWARE ONLY.	 DISCONNECTING MEANS SHALL BE PROVIDED TO DISCONNECT A FUSE FROM ALL SOURCES OF SUPPLY IF THE FUSE IS ENERGIZED FROM BOTH DIRECTIONS AND IS ACCESSIBLE TO OTHER THAN QUALIFIED PERSONS. SUCH A FUSE IN A PHOTOVOLTAK SOURCE CIRCUT SHALL BE CAPABLE OF BEING 		
Mathematical Control	WIRING AND WIRING METHODS:	DAMAGE PROTECTION:	DISCONNECTED INDEPENDENTLY OF FUSES IN OTHER PHOTOVOLTAIC SOURCE CIRCUITS. 9. ALL DISCONNECTS AND COMBINERS SHALL BE SECURED FROM UNAUTHORIZED AND UNQUALIFIED		
<text></text>	ALL WIRING METHODS AND INSTALLATION PRACTICES SHALL CONFORM TO THE NATIONAL ELECTRIC CODE, LOCAL STATE CODES, AND OTHER APPLICABLE LOCAL CODES.	 THE ELECTRICAL CONTRACTOR SHALL CONSIDER THE WEATHERING OF EQUIPMENT OVER TIME AND ELEMENTE THE POSSIBILITY OF DECRADATION DUE TO CORROSION, WATER ENTRY AND UV EXPOSURE. AS A RESULT, THE USE OF UNISTRUT OR SIMILAR MOUNTING SYSTEMS IS REQUIRED TO MOUNT 	PERSONNEL BY ETHER LOCK OR LOCATION.		
<text></text>	1. ALL EXPOSED CABLES, SUCH AS MODULE LEADS SHALL BE SECURED WITH MECHANICAL OR OTHER APPROVED SUN-LIGHT RESISTANT MERANS. THE USE OP PLASTIC 22 THES IS NOT AN APPROVED METHOD	ENCLOSURES, PULL BOXES, LOAD CENTERS, FUSE BOXES, OR OTHER EQUIPMENT. 2. ALL NEMA 4 BOXES SHALL BE EQUIPPED WITH LISTED DRAIN PLUGS INSTALLED TO ALLOW WATER TO DOANN AND MODEL TO TO A SHALL BE COURSE OF SUITURE AND AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOANN AND MODEL TO TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALLED TO ALLOW WATER TO DOADN AND MODEL TO TO TO TO A SHALL BE COURSE OF SUITURE AND TO BE DOADS IN STALL BE DOADS IN STALLED TO ALLOW WATER TO DOADN AND MODEL TO TO TO TO TO A SHALL BE TO DOADN TO TO ALLOW AND AS TO DOADN AND TO A SHALL BE DOADD TO A SHALL BE DOADD TO TO TO A SHALL BE DOADD TO A SHALL BE DO	REQUIRED SAFETY SICHS AND LABELS SHALL BE ETCHED PLACARDS PERMANENTLY ATTACHED BY ADHESIVE. OR OTHER MECHANICAL MEANS. LABELS SHALL COMPLY WITH ARTICLE 690 OF THE NEC OR OTHER		
<text></text>	TO SUPPORT OR ATTACH WIRE TO A STRUCTURE; THESE ARE ONLY PERMITTED FOR SUPPLEMENTAL GROUPING OR BUNDLING CONDUCTORS INSIDE OF EQUIPMENT. HEYCO SUNRUNNER PV SPECIFIC STAINLESS STEFL CIPS AND HEYCO SUNRUNDUE PUNVL LACKTED STEFL CARLES THES OR AN	MARTAN ALL LISTE DATING. ALL NEMA 3 ROXES SHALL BE FOURPED WITH A WEEP HOLE OR LISTED DRAIN PLUGS INSTALLED TO	APPLICABLE STATE AND LOCAL CODES. SEE LABELS AND MARKING PAGE FOR MORE INFORMATION. WEAR PERSONAL PROTECTIVE EQUIPMENT(PPE) APPROPRIATE FOR THE HAZARD: INSULATED GLOVES WITH		D
	APPROVED EQUAL ARE ALLOWED FOR USE IN THIS APPLICATION. 2. WIRE COLOR SPECIFICATIONS:	ALLOW WATER TO DRAIN. 4. ALL OUTDOOR ENCLOSURES REQUIRE AN APPROVED MEANS OF DRAINAGE AND VENTH ATION	PROTECTORS, INSULATED MATS AND TOOLS. 1. ANY SWITCH, FUSES, OR CIRCUIT BREAKERS THAT CAN BE ENERGIZED IN EITHER DIRECTION SHALL BE ADDRESS FOR FOR FOR ADDRESS.		v @
	AC WIRE COLOR CHART	 ALL ELECTRICAL CONDUIT, EQUIPMENT AND COMPONENTS MUST BE ADEQUATELY PROTECTED FROM DAMAGE AND VANDAUS MY THE USE OF ROLLARDS. SHIFLING CULARDS OR OF UPD ACCORDANCE LARDS. 	LABELED AS FOLLOWS: WARNING:		N 5 4
	AC CONDUCTORS 277 / 480 Volt 120 / 208 Volt	6. ALL CIRCUIT BREAKERS INSTALLED THAT ARE SUBJECT TO REVERSE DOWER FLOW SHALL BE LISTED AND LABELED AS BACKFED COMPATIBLE.	ELECTIONAL SHOCK NACAND DUNOT LOUCH TERMINALS. TERMINALS ON BOTH THE LINE AND LOAD SIDES MAY BE ENERGIZED IN THE OPEN POSITION		
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><form></form></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	Phase A BROWN BLACK Phase B ORANGE RED	ALUMINUM CONDUCTOR INSTALLATION NOTES:	2. THIS PHOTOVOLTAIC SYSTEM WILL BE EQUIPPED WITH DC DISCONNECTING COMBINERS WHICH WILL BE LABELED AS FOLLOWS:		
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	Phase C YELLOW BLUE Grounded Conductor GRAY or WHITE WHITE	MINIMUM WIRE SIZE FOR CURRENT CARRYING CONDUCTORS WHEN IMPLEMENTING ALUMINUM AS A CONDUCTOR SHALL BE 1/0 AWG STRANDED, COMPACT ELECTRICAL GRADE AA-8000 SERIES ALLOY.	PHOTOVOLTAIC DISCONNECTING COMBINERS		ILOO I tog
	Grounding Conductor GREEN or BARE GREEN or BARE Grounding Electrode Conductor GREEN W/ ORANGE GREEN W/ ORANGE	2. ALLMINUM POWER CABLE, WIRE CONNECTORS, AND INSULATING AND CODING TAPE MANUFACTURERS SHALL BE APPROVED BY SUNEDISON PRIOR TO USAGE.	 THIS PHOTOVOLTAIC SYSTEM WILL BE EQUIPPED WITH AN AC DISCONNECT WHICH WILL BE LABELED AS FOLLOWS: 		
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	DC WIRE COLOR CHART	 WHERE BOLTED CONNECTIONS ARE NOT POSSIBLE, MECHANICAL SCREW STYLE LUGS AND TERMINATIONS ARE APPROVED ONLY WHEN USED IN CONJUNCTION WITH A LISTED COPPER PIGTAIL 	PHOTOVOLTAIC DISCONNECTIVG MEANS A.C. DISCONNECT		1150 E # 2
<text><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></text>	SYSTEM TYPE DC CONDUCTORS POSITIVE (+) NEGATIVE (-) GROUND	 USE OF A 'ONE-SHOT' CRIMPER OR 'DIE-LESS CRIMPERS' WILL NOT BE ALLOWED. 	4. A MARKING SPECIFYING THE PHOTOVOLTAIC POWER SOURCE RATED AS FOLLOWS SHALL BE PROVIDED AT AN ACCESSIBLE LOCATION AT THE DISCONNECTION MEANS FOR THE POWER SOURCE:		
<form><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></form>	Ungrounded (Floating Systems) RED BLACK Positive Grounded Systems WHITE or GRAY BLACK GREEN or BARE	5. COMPRESSION STYLE LUGS AND TERMINATIONS SHALL BE RATED FOR THE MAXIMUM DC AND AC VOLTAGE OF THE SYSTEM. 4.1. INTER DE PLE IL LED NUTL OVER INTERTOD	OPERATING CURRENT OPERATING VOLTAGE MARMINI SYSTEM VOLTAGE SHOPET CURVIT CURPERNT		
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	Negative Grounded Systems RED WHITE or GRAY NOTE: CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR (INSULATION TYPE; COLOR, & CONTRACTOR IS SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE; COLOR, & CONTRACTOR IS SUBMIT WIRE SPECIFICATIONS (INSULATION)	 and the preventies of the strength of the strengt	COMBINER 5. ANY JUNCTION BOX, COMBINER BOX, DISCONNECT, AND DEVICE WHERE ENERGIZED UNGROUNDED DC CIRCUTS MAY BE EXPOSED DURING SERVICE:		
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	2. PV STRING HOME RUNS SHALL BE LABELED ON BOTH ENDS, AT ARRAY AND AT COMBINER OUTPUT CONDUCTORS SHALL BE LABELED AT BOTH ENDS, AT COMBINER AND AT DISCONNECT.	 OXDE INHIBITOR MUST BE APPLIED TO EXPOSED CONDUCTOR IMMEDIATELY AFTER STRIPPING AND BRUISHING AND IMMEDIATELY PRIOR TO INSTALLATION OF THE LUG. USE COMPRESSION TOOL LISTEP FOR USE WITH SELECTED COMPRESSION CONNECTOR. 	WARNING: ELECTRICAL SHOCK HAZARD THE CONDUCTORS OF THIS PHOTOVOLTAIC SYSTEM		PROJECT NUMBER: CA-15-1043
<list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item>	 LIQUID TIGHT FLEXIBLE METAL CONDUIT IS GENERALLY SUITABLE FOR INSTALLATION IN WET AND DRY LOCATIONS. SHOULD IT BE EMPLOYED, SUPPORTS WILL BE NO MORE 12 INCHES FROM BOXES (JUNCTION DOX. CONDUCTE DTRUCK, AND NO KODE TUNK LINGUIDS ADDRESS OF 2010 DRY DRY CONDUCTION DRY DRY DRY DRY DRY DRY DRY DRY DRY DRY	5.5. A MINIMUM 9" LENGTH OF COLD OR HEAT SHRINK WITH A VOLTAGE RATING EQUAL TO THE CONDUCTOR SHALL BE APPLIED TO COVER THE CONNECTION BETWEEN CRMP AND THE CONDUCTOR	ARE UNGROUND AND MAY BE ENERGIZED		SHEET TITLE:
<text><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item><list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></list-item></text>	 THE PHOTOVOLTAIC SOURCE CIRCUITS AND PHOTOVOLTAIC OUTPUT CIRCUITS OF THIS PROPOSED SOLD SYNTEM SUML NOT BE CONTAINED IN THE SAME BACEWAY, CABLE OUTPUT TRAY, CABLE OUTPUT BOY 	SECURING AT THE STRAIGHT SECTION OF THE CRIMP. 5.6. ALL CONNECTORS AND CORRESPONDING CRIMPING TOOLS SHALL BE ULLISTED FOR THEIR SOBCIECT ADDI LOTION	ALL INTERACTIVE SYSTEM POINTS OF INTERCONNECTION WITH OTHER SOURCES SHALL BE MARKED AT AN ACCESSIBLE LOCATION AT THE DISCONNECTION MEANS	ELECTRICAL SYMBOLS	- ELECTRICAL NOTES
<text><text><list-item> A. Suman and a series of a series of</list-item></text></text>	JUNCTION BOX, OR SIMILAR FITTING AS FEEDERS OR BRANCH CIRCUITS OF OTHER SYSTEMS UNLESS THE CONDUCTORS OF THE DIFFERENT SYSTEMS ARE SEPARATED BY A PARTITION OR ARE CONNECTED TOGETHER.	IDENE AND COLOR CODING TAPE SHALL BE PREMIUM GRADE PRESSURE SENSITIVE VINYL, HEAT/COLDMOISTURE/SUNLICHT/ RESISTANT. INSULATING TAPE SHALL BE BLACK AND COLOR CODING	 A PERMANENT ETCHED PLAQUE OR DIRECTORY SHALL BE PROVIDED IDENTIFYING THE LOCATION OF THE SERVICE DISCONNECTION MEANS AND THE PHOTOVOLTAIC SYSTEM DISCONNECTION MEANS, IF NOT 	TRANSFORMER	
<form> </form>	 UNLESS MARKED AS UV RESISTANT, PVC IS NOT APPROVED FOR INSTALLATION IN LOCATIONS SUBJECTED TO DIRECT SUNLIGHT AND SHALL NOT BE EMPLOYED IN ANY SUCH LOCATION. 	TAPE SHALL BE FADE RESISTANT. 7. FOR ALUMINUM MV CONDUCTORS, WHERE USED, THE GUIDELINES IN THIS SECTION PLUS GENERAL	LOCATED AT THE SAME LOCATION. 3. ALL REQUIRED EQUIPMENT SHALL BE ULLISTED AND LABELED ACCORDINGLY.	°∽ SWITCH	SHEET SIZE: ARCH "D" 24" X 26" (610 x 014)
<form> Normal And And And And And And And And And And</form>	 LONG STRAIGHT EXPOSED METAL CONDUIT (RMC, GRC, EMT) RUNS, 100 FEET OR MORE, SHALL HAVE EXPANSION FITTINGS INSTALLED PER NEC 300.7(B). EXPANSION FITTINGS SHALL ALSO BE USED WHEN CONTRUE OF LONG AN UPPER INFORM (OPPER) 	REQUIREMENTS FOR MY CONDUCTOR INSTALLATION SHALL APPLY. 8. DIRECT LANDING OF ALUMINUM CONDUCTORS IS ONLY ALLOWED TO BREAKERS WHICH ARE SPECIFICALLY PARTED FOR ALLAMINUM CONDUCTORS.	 ALL PULL BOXES SHOULD BE PERMANENTLY MARKED WITH EITHER "ELECTRIC" OR "COMMUNICATION" DEPENDING ON THE APPLICATION, PER NEC 110.75(E). 	INVERTER	<u>0 k</u> 1"
 a) a. Let returne ret	COMPUT OF AND AN EAPANDRUM JUENT. 8. FUSES AND WIRES SUBJECT TO TRANSFORMER INRUSH CURRENT SHALL BE SIZED ACCORDINGLY.	GROUNDING:			THIS DRAWING IS THE PROPERTY OF SUNEDISON, LLC. THIS INFORMATION IS CONFIDENTIAL AND IS TO BE USED ONLY IN CONNECTION WITH WORK
 Set and the set a	9. ALL DC MATERIALS SHALL BE ULLISTED FOR 1000V DC. 10. WHEN TRANSITIONING UNDERGROUND PVC CONDUCT TO ABOVE GROUND RMC BPC OP DATE CONDUCT USE	SEE ELECTRICAL DIAGRAM AND ELECTRICAL DETAILS FOR MORE GROUNDING INFORMATION.		U FUSE.	B DESCRIBED BY SUNEDISON, LLC. NO PART IS TO BE DISCLOSED TO OTHERS WITHOUT WRITTEN PERMISSION FROM SUNEDISON, LLC.
 Instrument of the state of the	METALLIC CONDUIT, AN EXPANSION JOINT SHALL BE USED IN THE TRANSITION TO ABOVE GROUND CONDUCTIVEREE FEDERATION OF 100 Sch	UNLET UNE CONNECTION TO UC CIRCUITS AND ONE CONNECTION TO AC CIRCUITS WILL BE USED FOR SYSTEM CROUNDING (NEC 690.42) (REFERENCED TO THE SAME POINT). EOUTIMETE CROINING CONNUCTORE AND SYSTEM CROINING CONNUCTORE		◦ ◦— I SURGE ARRESTOR	NO. REVISION DATE INIT
 Normal control metrical using the control metrical usin the control metrical using the control metrical using the co	11. ANY METAL SHAVINGS RESULTING FROM SITE WORK SHALL BE CLEANED FROM ENCLOSURE INTERIORS, TOP SURFACES OF ENCLOSURE, ROOP SURFACE, AND ANY ADDITIONAL AREAS WHERE OWNATION OR	DISTANCE TO GROUND AS POSSIBLE AND A MINIMUM NUMBER OF TURNS. NON-CIEPERNT CARPYING METAL PARTS SHALL BE CHECKED FOR DRADED COMMINING, MOTING THAT		600A NON-LOAD BREAK ELBOW	1 MODULE 10-14-16 DRI 2 CITY COMMENTS 11-09-16 DRI
NUMBER OR NALTA ALLECES TO THE ENTRY FOR THE ELECTRCAL QUERNESS. 	CONDUCTIVE METAL SHAVINGS MAY CAUSE RUST, ELECTRICAL SHORT CIRCUIT OR OTHER DAMAGE. 12. CONDUITS LONGER THAN 200 FT WITH NEGATIVE SLOPE TOWARD ELECTRICAL EQUIPMENT SHALL HAVE A	TRAVESSMENT CHARTEN BELIEF AND STRALL BE CHECKED FOR FRAVER ORDUNING, NOLDING, NO	EQUIPMENT LABELING KEY		
USE OF PRIVENT THE LEW THY OF MORTHEE 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL 14. NOT OF CONTROL	PULL BOX OR VAULT ADJACENT TO THE ENTRY POINT INTO THE ELECTRICAL EQUIPMENT. 13. WHEN TRANSITIONING FROM FREE AIR TO CONDUCTORS IN CONDULT A LISTED FITTING SHALL BE	4. RACKING COMPONENTS AND STRUCTURAL SUPPORTS MUST BE ELECTRICALLY BONDED TOGETHER BY AN ACCEPTABLE MEANS.	POINT OF CONNECTION TRANSFORMER	IT=31 TRANSFORMER NUMBER	DSA IDENTIFICATION STAMP:
 A LA CAD DC COPPET TERMENTONIS SILLI ARE REPORTING SILLI	USED TO PREVENT THE ENTRY OF MOISTURE. 14. L AND T CONDUIT BODIES SHALL NOT BE USED.	 MODULES SHALL BE GROUNDED WITH EQUIPMENT GROUNDING METHODS APPROVED BY THE MANUFACTURER WITH A MEANS OF BONDING LISTED FOR THIS PURPOSE. 	PC_<##> XFR_##	SC1 SECTIONALIZED CABINET NUMBER	
 Control we way that is a structure we way that structure we way tha	15. ALL AC AND DC COPPER TERMINATION(S) SHALL HAVE KOPR SHIELD OR EQUIVALENT APPLIED.	 THE CONNECTION TO THE MODULE OR PANEL OF THIS PROPOSED SOLAR ELECTRIC SYSTEM SHALL BE SO ARRANGED THAT REMOVAL OF A MODULE OR A PANEL FROM THE PHOTOVOLTAC SOURCE CIRCUIT DOES NOT INTERRUPT A CROUNDED CONDUCTOR TO ANOTHER PHOTOVOLTAC SOURCE CIRCUIT. SETS OF 	PC_01 XFR_01	© REFERS TO CABLE SCHEDULE.	
11. SECRET NOT DIALAGE THE RECEIPTION OR SOCIETY CONNECT THE PERSON ROLL GROUNDON STATUS CONNECT CONNECT THE PERSON ROLL GROUNDON CONNECT STATUS CONNECT TO THE PERSON ROLL GROUNDON CONNECT THE PERSON ROLL GROUNDON CONNECT STATUS CONNECT TO THE PERSON ROLL GROUND CONNECT STATUS CONNECT TO THE PERSON ROLL GROUND CONNECT STATUS CONNECT THE PERSON ROLL GROUND CONNECT STATUS CONNECT TO THE PERSON ROLL GROUND CONNECT STATUS CONNECT TO THE PERSON ROL GROUP	CIRCUTS ADDALE OF ONE OF A LODGE ALL ON OUR FUR ALL ALL CIRCUTS 480 V OK BELOW AND DC CIRCUTS 600 V OR BELOW. MEGGEN ETSCHWIGT MEI BE PREPORTED AT 1500 VDC FOR DC CIRCUTS N 1000 VDC SYSTEMS. A MINIMUM OF 250 MEGAOIMS RESISTANCE TO GROUND IS REQUIRED. DO NOT MEGGEN THE SOLRA MODULES AS DAMAGEN WOULD IRERV RESULT.	MODULES INTERCONNECTED AS SYSTEMS BATED AT 50 VOLTS OR LESS WITH OR WITHOUT BLOCKNC DIODES, AND HAVING A SINGLE OVER CURRENT DEVICE SHALL BE CONSIDERED AS A SINGLE SOURCE CIRCUIT.	IDENTIFIER	(w10) MV CABLE IDENTIFICATION NUMBER	
19. SUPPORT CODUCTORS IN VERTICAL CONDUCTORS IN VERTICAL CONDUCTIONS IN UNDERCEPTING CONTACTOR IS TO DESCRICT VERSING OF SURVICIAL VERSING	17. BENDS SHALL NOT DAMAGE THE RACEWAY OR SIGNIFICANTLY CHANGE THE INTERNAL DIAMETER OF RACEWAY PER TABLE 2 OF THE NEC.	 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, INCLUDING BUT NOT LIMITED TO GROUND RODS, GROUNDING LUGS, GROUNDING CLAMPS, ETC. 	IDENTITIEN -		DATE: 22-06-2016 DRAWN BY: JW
10. CONNECTORS TO DE TODUET DE STACL LETTA ON AUMAFECTURERS RECOMMENDATIONS 11. CONNECTORS TO DE TODUET DE STACL LETTA ON AUMAFECTURERS RECOMMENDATIONS 12. CONNECTORS STALL DE NOTATIONS PAINT AFTER STACL CONNECTION TO THE GEN CONTACT WITH DESSBELAR METALS. 13. DE NELESCONFECTORS SHALL DE NOTATIONS PAINT AFTER STALL CONNECTION TO THE GEN CONTACT WITH DESSBELAR METALS. 13. DE NELESCONFECTORS SHALL DE NOTATION TO MELE DESS MULL DE NOTATION TO THE GEN CONTACT WITH DESSBELAR METALS. 13. DE NELESCONFECTORS SHALL DE NOTATION TO MELE DESSBELAR METALS. 14. DEMONSCONFECTORS SHALL DE NOTATION TO MELE DESS MULL DE NOTATION TO MELECE TONS DE STALL DE NOTATION TO MELECE TONS DE NOTATION TO MELECE TONS DE STALL DE NOTATION TO MELECE TONS DE STALL DE NOTATION TO MELECE TONS DE STALL DE NOTATION TO MELECE TON	18. SUPPORT CONDUCTORS IN VERTICAL CONDUITS IN ACCORDANCE WITH THE REQUIREMENTS OF NEC 300.19.	 WHERE USED, GROUND LUGS SHALL BE RATED FOR DIRECT BURIAL (DB RATED). CONTRACTOR IS TO SUPPLY DOCUMENTATION PROVING THIS DURING PRODUCT SUBMITTALS. 	STRING INVERTER	Δ DELTA CONNECTION	A APPROVED BY: [XXX]
10. ALL BASE CU WRETS SIALL BE INSTALLED TO NOT COME BYTO CONTACT WITH DESSBELAR METALS. WITHEN 11. BUTCH DESTRONG TO NOT SIALL BE INSTALLED TO NOT COME BYTO CONTACT WITH DESSBELAR METALS. INVENTO: 12. BUTCH DESTRONG TO NOT SIALL BE INSTALLED TO NOT COME BYTO CONTACT WITH DESSBELAR METALS. INVENTO: 13. BUTCH DESTRONG TO NOT SIALL BE INSTALLED TO NOT COME BYTO NOT COME BYTO DESTRONG TO NOT SIALL BE DESTRONG TO NOT SIAL BYTO DESTRONG TO NO	19. CONNECTORS TO BE TORQUED PER DEVICE LISTING, OR MANUFACTURERS RECOMMENDATIONS. CONNECTORS ARE TO BE MARKED WITH PERMANENT MARKING PAINT, AFTER TORQUEING.	9. BONDING PAINTED COMPONENTS. 10. ALL RACEWAYS AND ENCLOSURES WILL REQUIRE A PHYSICAL CONNECTION TO THE GEC CONTAINED	STR_ <inverter##>_## INV_##</inverter##>	Y WYE CONNECTION	PROJECT PHASE: INITIAL DESIGN
11. Production for approximation production product in exclusion and matching approximation of the product in exclusion and matching approximatin exclusion and matching approximation and matching appr	20. ALL BARE CU WIRES SHALL BE INSTALLED TO NOT COME INTO CONTACT WITH DISSIMILAR METALS .		STR_01_01 INV_01 STRING		SCALE:
IZ ATTERNATE THIS NOTE WILL BE SUPERCEDED BY ANY NVERTER SPECIFICATIONS REQUEING UV AC WIRE TO MEET HIGHER VOLTAGE OR INSULATION STADDADDS. CANOPY DEA TEMPLATE RELEASE 1.1	 SPILES-CONNECTORS SHALL BE INSULATED AND WILL REQUIRE PROJECT EXGENEER APPROVAL UL LISTED ELECTRICAL TAPE ALONE ES NOT SUITABLE AS THE NOLY INSULATION MEANS, FOLLOW MANUFACTURERS INSTRUCTIONS FOR INSTALLATION, AND APPLICATION OF INSULATING PRODUCT. 	HOTOVOLTAC INVERTERS SHALL BE EQUIPPED WITH ANTIGATION FAULT PROTECTION TO REDUCE FIRE HAZARDS. INVERTERS ARE ALSO EQUIPPED WITH ANTISLANDING CIRCUITRY.	INVERTER/ IDENTIFIER/		SHEET NO.:
CANOPY DSA TEMPLATE RELEASE 1.1	22. ALTERNATE. THIS NOTE WILL BE SUPERCEDED BY ANY INVERTER SPECIFICATIONS REQUIRING LV AC WIRE TO MEET HIGHER VOLTAGE OR INSULATION STANDARDS.				E-001
	CANOPY DSA TEMPLATE RELEASE 1.1			Revision #17 12/03/202	15

Exhibit B - Development Plans

	<u>veropinent i ians</u>
1 2 3 4 5 6 <u>CENERAL MEDIUM VOLTAGE NOTES:</u> 1. ELEDINS, BUSHINGS, AND TEST CAPS MAST BE CLEAN AND PROPERTY LUBRICATED.	ANUFACTURERS I SunEdison
2. POWER CARLE, ELBOW, AND MY. TERMINATION DRAWS SHALL BE INSTALLED IN A MANNER THAT WILL ALLOW FOR THE REMOVAL, STANDING OFF, AND/OR LANDING OFF, ADD/OR LANDING OFF, ADD/OR SHALL WITH CARLE COMPARISATION SHALL WITH CARLE COMPARISATION SHALL BE INTERCARD. WITH CARLE COMPARISATION SHALL COMPARISATION SHALL BE INTERCARD. WITH CARLE COMP	DUT THE NEED TO LABEL FAULT
3. TAPE SHIELD ADAPTER KITS ARE TO BE USED WITH POWER CABLE THAT HAS TAPE SHIELDING. 11. ALL 600 YOLT CLASS AC WIBING SHALL BE COPPER WIRE; TYPE THENTHINN 2 RATED / AND RATED FOR 600Y, OR APPROVED EQUAL	AT 90 DEGREES C, (650) 453-5600 www.sunedison.com
4. THE MEDILAVICIAGE SYSTEM IS DESIGNED TO BE A [pc:x07]. MARKET, SWITER PLOY BOOK AND A CONTRACT AND A CONT	E
5. ALL MEDIUM VOLTAGE WORK SHALL COMPLY WITH THE LATEST EDITION OF ANSIC 2- NATIONAL ELECTRICAL SAFETY CODE (NESC) ELECTRICAL SAFETY (NESC) ELECTRICAL SAFET	COGNIZED TESTING HE APPLICATION.
6. MEDIUM VOLTAGE CABLES 6. MEDIUM VOLTAGE CABLES 7. PROVIDE DANGER, WARNING, AND CAUTION LABLES AS REQUIRED BY NESC, OR OSHA 8// RED. 7. SING PROVIDE DANGER, WARNING, AND CAUTION LABLES AS REQUIRED BY NESC, OR OSHA 6// REVIEW AND AGRESSING DEVIEW AND AGRES	I STANDARDS ON AEDIUM VOLTAGE
OR INSTALLATION OF THE FOLLOWING CECUSY OR INSTALLATION OF THE FOLLOWING CECUSY OR INSTALLATION OF THE FOLLOWING CECUSY OR INSTALLATION OR INSTALLATION OF THE FOLLOWING CECUSY OR INSTALLATION OR INTERNATION OR INT	E PADLOCKABLE AT OVER 600V STAMP:
MIX SMTCH MIX SMTCH VOLTAGE COUPMENT INSTALLED OUTSUC OF FERCES WERE ACCESSIBLE VOLTAGE CONTINUE (TO THE STANG AGENCY) TO PERFORM ACCEPTANCE TESTING PER SPECIFICATION SECTION 1080. SECT	TO THE PUBLIC
ALL EQUIPMENT INCLUDING SWITCHGEAR, SECTIONALZING CABINETS, TRANSFORMERS, ETC. SHALL BE MICHORED TO CONSERTE TAGS OF COUNSATIONS PER MANUE LABLED ON THE FROMT EXTERNOR TO CORRESPOND TO THE DECOMPOSITION OF MICH POLY DOWNING WITH OUTDOORS (FREELETING, ADDRESS LEBES, BLECK/IFE/CATING BLECK/I	ACTURER'S TH 6 INCH DEEP I.
L HAUE A LI LEVENIN VO TACE ARE ESSUAL DE LASCED AT EAVENING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSING CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED WITH AUVANZED STEEL PLATE OF PROVENSION CONSERVIS SUAL DE SEALED STEEL PLATE SEALED STEEL PLATE SEALED STEEL SEALED STEEL PLATE SEALED S	R SCREEN TO
EQUIPHINT ENCLOSUBLE WITH DEQUIT AND PHASE DESTINGENTS TO DREESPOND TO THE DEVANING. LAGE SIGNAL CONSTRUCTION DESTINGUES TO THE DEVANCE AND TO THE DEVANING. LAGE SIGNAL CONSTRUCTION DESTINGUES TO THE DEVANCE AND	D PREVENT WATER
EMALDISINE WITHOU FRAUMING INSULE VER WOMING CARLES. 10. ARRANGE PHASES IN SWITCHEARA, SECTIONALIZAR, CALE AF CFROM LEFT TO RIGHT OR 10. FOR TOTAL AS VERSION THE FRAUTH EFF FOR THE FRAUE FRA	
11. VERIFY UTLITY PHASE SEQUENCE AND COORDWITE INSTALLATION OF FEEDER CONDUCTORS TO ADD AT THE ROUTED TO MUNITAR ACCESS TO ADDCATORS, VULVES, PROVIDE CORRECT PHASE SEQUENCE AT INVERTER SIDE OF STEP-UP TRANSFORMERS.	
12. PROVIDE ARC FLASH HAZARD WARNING LABELS COMPLYING WITH ANSI 233.6 ON ALL EQUIPMENT. 10. PLACE MICARTA NAMEPLATES WITH MINIMUM 3/4 'HGH LETERS FOR DISTRIBUTION EN LABELS SHALL BE APPLED ON BOTH INSIDE AND OUTSIDE DOORS OR BARRERS OF OUTDOOR SING MARRERS OF OUTDOOR SING MARRERS OF OUTDOOR SING MARRERS OF OUTDOOR SING MARRERS OF OUTDOOR SING MARRENS OF OUTDOOR SI	
1. PROVIDE KEMA 4 ENCLOSURE WHERE MALABLE FOR EXTERIOR DC AND U VEQUIPME 13. ALL EQUIPMENT LABELING SHALL COMPLY WITH SUN DEISON REQUIREMENTS. 14. ENCLOSURE UND SHALL COMPLY WITH SUN DEISON REQUIREMENTS.	
14. Edulmenti MU COMPORI SIMULE INTELLIMA DELELETARI MA INAUXE PRO TINE ANTINAUXE PRO TINE APPLICATION AND ANTINAUXE PRO TINE ANTINAUXE	
EQUIPMENT ENC.OSURES, DOORS, ACCESS PLATES, AND BARRIERS AND LABEL ALL MEDIUM VOLTAGE. EQUIPMENT WITH THE OPERATING VOLTAGE. III TRANSFORMERS SINGLI BE SECURELY BOLTED TO THE EQUIPMENT PAD AND MODE LE BETWEEN THE PAD AND BASE OF THE TRANSFORMER MUST BE SECURE.) III THE PAD AND BASE OF THE TRANSFORMER MUST BE SECURE.)	
CONDUITS AND DUCTBANKS: C CONDUITS FOR DIRECT BURAL DE CONCRETE BIXASEMENT SHALL BE SCHEDULE 40 PVC. PROPER TORQUE SHALL BIE APPLIED TO ALL BUSINISS AS INDICATED. PROPER TORQUE SHALL BUSINISS AS INDICATED. PROPER TORQUE SHALL BUSINISS AS INDICATED. PROPER TORQUE SHALL BUSINISS AS INDICATED. PROPER TORQU	
ALL UEDULUV VO TAGE CONDUTS SINLE HAVE MINIMUM 60 INCH ROLLIS SINCEPS EXCEPT 36 INCH (STATEMENT OF VOLTAGE), NID TRANSFORMER DOORS (DANGER WARNING). MINIMUM RADUS IS REQUIRED FOR VERTICAL SINCEPS IP TO EQUIPMENT. MEMA DRILLED LONG BARREL COMPRESSION LUGS TO BE USED FOR THE LOW VOLTAGE	GE WIRE.
AMAY HAM MIMIMAD IN BUCHES OF SPACARCH RURZCAN HALT AND	CA-15-1043
AMARTAM MINIMUM FOOT SPACING BETWEEN NEIDIM VIS. CEF CORE VIS. ALL CONDUCTORS SHALL BE ROUTED TO MAINTAIN ACCESS TO MICRATORS, VILVES, ETHER ORGALITY UNLESS THE OUCLUATIONS SECTIONS INDICATE CLOSER SPACINGS WHICH HAVE BEEN SMITCHSE. THE OVAILAGE AND OTHER COMPONENTS AND ACCESSORE OPERATION SECTIONS INDICATE CLOSER SPACINGS WHICH HAVE BEEN SMITCHSE. THE OVAILAGE AND OTHER COMPONENTS AND ACCESSORE	SAMPLE PORTS, IS REQUIRING MEDILIM VOL TACE
MAINTAIN ALL CONDUIT ENTRIES TO EQUIPMENT WITHIN MANUFACTURER'S DESIGNATED CONDUIT VERIFY THE FOLLOWING: ENTRY SYACE AND ARRANGE CONDUITS TO FRENIT THE IMBUST DIRECT ROUTING OF ALBUST TO T. FACTORY WIRKING DIAGRAM IS ACCURATE TERRINALS AND TO ALLOWING DIAGRAM AND ARRANGE CONDUITS TO FRENIT THE MOST DIRECT ROUTING OF ALBUST TERRINALS AND TO ALLOWING DIAGRAM IS ACCURATE TERRINALS AND TO ALLOWING DIAGRAM IS ACCURATE	ELECTRICAL NOTES
Constraints and Laboration Connect Lots. To device the Annual Addition Connect Lots. To device the Addition Connect Lots.	AMPARIMENT VALVE AND OIL ARCH "D" 24" X 36" (610 x 914)
7. ALL CONDUITS ENTERING EQUIPMENT TO BE EQUIPPED WITH BELL ENDS TO PREVENT ABRASION. 8. PROVIDE 12" OF CLASS 5 GRAVEL DRAMAGE BEDDING UNDER THE GROUND SLEEVE.	THIS DRAWING IS THE PROPERTY OF SUNEDISON, LLC. THIS INFORMATION IS CONFIDENTIAL AND IS TO BE USED ONLY IN CONNECTION WITH WORK DESCRIBED BY SUNEDISON, LLC. NO PART IS TO
CONDUCTORS: 1. COMPLETELY INSTALLALL CONDUT RUINS AND BACKFLL DUCTBANKS BEFORE PULLING CABLE. PULL A RESUBJENT PRODUCE HACH CONDUT AFTER INSTALLATION. INSTALL A 3/* DIAMETER INFLOR PULL ROPE IN ALL SPARE CONDUITS.	BE DISCLOSED TO OTHERS WITHOUT WRITTEN PERMISSION FROM SUNCEISON, LLC. NO. REVISION DATE INIT. 1 MODULIE 10.14.18 DDMI
A MEDIAL NU CITAGE CONDUCTORS GIVILLE EVALUE DURSING DIRECT CONVECTION OF PULLING EVEST O TO CONDUCTORS OF CALLE IN THE CENCIL OF VERTIONAL MULLING EVEST O CONDUCTORS OF CALLEND ALEL INNER CENCIL OF VERTIONAL MULLING EVEST O CONDUCTORS OF CALLEND ALELING AND ALELING ALE INTERCENT OF CALLEND CONDUCTORS OF CALLEND ALELING AND ALELING ALE AND ALELING ALE AND ALE	2 CITY COMMENTS 11-09-16 DRM DSA IDENTIFICATION STAMP:
3. INSTALL HANDHOLES AS REQUIRED TO MINIMZE MXXMUM ALLOWABLE CABLE TENSION PER CABLE MANUFACTURER WHEN PULLING CABLES.	
4. SPLICES ARE NOT PERMITTED IN POWER OR CONTROL CONDUCTORS UNLESS INDICATED ON THE DRAWINGS OR APPROVED IN ADVANCE OF INSTALLATION BY ENGINEER AND OWNER.	
WHERE CONDUCTORS OF DFFERENT OFACUITS ASS THROUGH THE SAME INANOULE OR POLLIDAD. COVER THE CONDUCTORS OF FACE UNCOLORITISTIC ACROMINGTING THAN UNCOLORY EQUIVALENT. STRAT. WRAPPED HALF-LAPPED AND HELD IN PLACE WITH REVERSE WRAPPED GLASS FIBER TARE.	DATE: 22-06-2016
C C	DRAWN BY: JW ENGINEER: AF A APPROVED BY: [xxx]
C ALL MECHANICAL CONNECTIONS OTHER THAN BLOW CONNECTORS SHALL BE MADE USING ULLISTED TW-PATED COPPER CRECUMPERENTIAL COMPRESSION LUCS, LUCS SHALL BE LONG-BARREL WITH	PROJECT PHASE: INITIAL DESIGN SCALE: Iscale
NBMA TWO HOLE DEBLLINC, BURNOY IVILIC MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINC, BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL VAZ OR EQUIVALENT CONNECTED WITH HEIGHER DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS HEIGHER DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS HEIGHER DEBLLINCS BURNOY IVILIA DEBLLINCS BURNOY IVILICS MODEL DEBLLINCS BURNOS BUR	[]
SD NIMA TWO HOLE SHULPA. BRURNU TILCA MODEL VIA SA DE GRUNALEST CONDUCTOR HIGH IS THENOLTI SULCON TRACE AND ACCENT AND CANADICANE UNCENTOR HIGH IS THENOLTI SUCCONSTRUCT AND CANADICANE UNCENTOR THE HIGH IS THENOLTI SUCCONSTRUCT AND CANADICANE UNCENTOR HIGH IS THENOLTI SUCCONSTRUCT AND CANADICANE UNCENTOR HIGH IS THENOLTI SUCCONSTRUCT AND CANADICANE UNCENTOR HIGH IS THE AND CANADICANE UNCENTION UNCENT AND CANADICANE UNCENTION HIGH IS THE AND CANADICANE UNCENT UNCENT UNCENT AND CANADICANE UNCENTION UNCENT UNC	внеет NO.: E-002

Agenda Item 2

ICAL ELEC' 202

park\5.0

1043 å Q 8 oark/

ęb, Sync ∕Box

Agenda Item 2

Attachment 8 Draft Resolution B

RESOLUTION NO: 16-XXX

A RESOLUTION OF THE PLANNING COMMISSION OF THE CITY OF EL PASO DE ROBLES TO APPROVE CONDITIONAL USE PERMIT 16-005 SHERWOOD PARK 1860 Creston Road (APN: 009-311-019)

WHEREAS, Table 21.16.200 of the Zoning Ordinance of the City of El Paso de Robles requires a Conditional Use Permit (CUP) for public utilities facilities in the R-1 zone; and

WHEREAS, the applicant, SunEdison LLC, has filed a Conditional Use Permit (CUP) application proposing to install a photovoltaic system canopy structure within the existing parking lot of Sherwood Park located at 1860 Creston Road; and

WHEREAS, this application is Categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA) per Section 21080.35 of the Public Resources Code; and

WHEREAS, a duly noticed public hearing was conducted by the Planning Commission on December 13, 2016, to consider the facts as presented in the staff report prepared for this project, and to accept public testimony regarding this conditional use permit request; and

WHEREAS, based upon the facts and analysis presented in the staff report and public testimony received and subject to the conditions of approval listed below, the Planning Commission finds that the establishment, maintenance and operation for the requested use and building would be consistent with the General Plan and not be detrimental to the health, safety, morals, comfort, convenience and general welfare of the persons residing or working in the neighborhood of such proposed use, or be injurious or detrimental to property and improvements in the neighborhood or to the general welfare of the City.

NOW, THEREFORE, BE IT RESOLVED, that the Planning Commission of the City of El Paso de Robles does hereby approve Conditional Use Permit 16-005 subject to the following:

Section 1 - Findings: based upon the facts and analysis presented in the staff report, public testimony received and subject to the conditions listed below, the Planning Commission makes the following findings:

- 1. The proposed use is consistent with the General Plan and Zoning Ordinance; and
- 2. The proposed use satisfies the applicable provisions of the Zoning Ordinance; and
- 3. The establishment, and subsequent operation or conduct of the use will not, because of the circumstances and conditions applied in the particular case, be detrimental to the health, safety or welfare of the general public or persons residing or working in the neighborhood of the use, or be detrimental or injurious to property or improvements in the vicinity of the use; and

- 4. That the proposed project or use will not be inconsistent with the character of the immediate neighborhood or contrary to its orderly development; and
- 5. That the proposed use or project will not generate a volume of traffic beyond the safe capacity of all roads providing access to the project, either existing or to be improved in conjunction with the project, or beyond the normal traffic volume of the surrounding neighborhood; and

Section 2- Environmental Determination: This projects qualifies for as categorically Exempt from environmental review under the State's Guidelines to Implement the California Environmental Quality Act (CEQA) per Section 21080.35 of the Public Resources Code.

Section 3 - Approval: Conditional Use Permit 16-005 is approved subject to the following:

- 1. This Conditional Use Permit (CUP) authorizes the installation of a photovoltaic system canopy structure within the existing parking lot of Sherwood Park located at 1860 Creston Road as shown in Exhibit B (Development Plans).
- 2. The project shall be constructed so as to substantially conform with the following listed exhibits established by this resolution:

EXHIBIT	DESCRIPTION
А	Project Conditions
В	Development Plans

PASSED AND ADOPTED THIS 13th day of DECEMBER, 2016 by the following Roll Call Vote:

AYES:

NOES:

ABSENT:

ABSTAIN:

BOB ROLLINS, CHAIRMAN

ATTEST:

WARREN FRACE, SECRETARY OF THE PLANNING COMMISSION

Exhibit A Exhibit B

Exhibit A

Conditions of Approval – CUP 16-005

Planning Division Conditions:

- 1. The project shall be constructed so as to substantially conform with Exhibit B (Development Plans).
- 2. Prior to issuance of the building permit, the applicant shall submit for review and approval the selected color sample, as determined by the Community Development Department, for the steel component of the canopy structure.
- 3. All lighting shall be downward directed and shielded to prevent offsite glare in conformance with Section 21.21.040 of the City's Zoning Ordinance.
- 4. Upon completion of the construction of the project, the public property and any improvements thereon shall be restored to a good and safe condition.
- 5. Any condition imposed by the Planning Commission in granting this Conditional Use Permit may be modified or eliminated, or new conditions may be added, provided that the Planning Commission shall first conduct a public hearing in the same manner as required for the granting of the original permit. No such modification shall be made unless the Commission finds that such modification is necessary to protect the public interest and/or neighboring properties, or, in the case of deletion of an existing condition, that such action is necessary to permit reasonable operation and use under the Conditional Use Permit.

Emergency Services Conditions:

- 6. All hazardous electrical transmission lines must be labeled "CAUTION Electrical Hazard".
- 7. Warning labels shall appear on the utility interactive inverter or be applied by the installer near the ground fault indicator at a visible location stating the following:
 - a. Warning Electrical Shock Hazard
- 8. Shut down and/or isolation procedures will be clearly displayed on the main electrical service panel exterior shunt trip device designed to terminate power to all electrical service (solar and domestic) when the main service disconnect is in the off position.
- 9. Main electrical service panel shall be labeled "Solar Power Enhanced"

Agenda Item 2				Exhibit B - Deve	elopment Plans
The second of t		SHERWO 1860 CRES PASO ROBL	STON ROAD, ES, CA, 93446	E	
НЕКМО			30% E	DESIGN	
Idona/Projects/City or Paso Robles/CA-15-1044 Sherwood Park/100 AOUX/CA-15-1044 S		DECT	<section-header><section-header><text><text><list-item><list-item><list-item><text></text></list-item></list-item></list-item></text></text></section-header></section-header>	GENERAL Sheet Rev. Sheet Title G-001 TITLE SHEET G-002 G-002 GENERAL NOTES GENERAL NOTES Sheet ARCHITECTURAL Sheet Title A-101 MASTER SITE PLAN A-201 A-201 ARCHITECTURAL RENDERINGS A-201 A-501 ACCESSIBILITY DETALS GENERAL NOTES E-001 ELECTRICAL NOTES ELECTRICAL NOTES E-002 MEDIUM VOLTAGE ELECTRICAL NOTES E-101 E-003 MEDIUM VOLTAGE ELECTRICAL NOTES E-101 E-004 ELECTRICAL NOTES E-101 E-005 MEDIUM VOLTAGE ELECTRICAL NOTES E-501 E-006 EQUIPMENT LABELS AND DETAILS E-502 E-507 ELECTRICAL CANOPY DETAILS E-506 E-508 EQUIPMENT LABELS AND DETAILS E-506 E-509 EQUIPMENT LABELS AND DETAILS E-506	C SHERWOOD PARK CITY OF PASO ROBLES 1860 CRESTON ROAD, PASO ROBLES, CA, 933446
PROJECT DEVELOPER SUNEDISON 600 CLIPPER DRIVE BELMONT, CA, 94002 (660) 435-5600 PROJECT ENGINEER ANTHONY FERREIRA ANTHONY FERREIRA ANTHONY FERREIRA ANTHONY FERREIRA	SITE CONTACT [name] [address] [dty] [state] [2p] [phone]	SCOPE OF WORK THIS DESIGN PACKAGE PROVIDES DRAWINGS FOR THE INSTALLATION OF A 280.8 KW DC RATED PHOTOVOLTAIC SYSTEM AT 1880 CRESTON ROAD, IN PAI ROBLES, CA. ENVIRONMENTAL PLANS ARE NOT PART OF THE SCOPE OF THIS PLAN SET.	APPLICABLE CODES AND STANDARDS • CALFORNIA BUILDING CODE (GRC) 2013 EDITION • CALFORNIA ENERCY CODE 2013 • CALFORNIA FIRE CODE 2013 EDITION • CALFORNIA FIRE CODE 2013 EDITION • CALFORNIA MECHANICAL CODE 2013 EDITION • CALFORNIA FILE CODE, AND EDITION • CALFORNIA FILE CODE AND EDITON • CALFORNIA FILE CODE AND EDITON • CALFORNIA FILE CODE AND EDITON • CALFORNIA FILE CODE AND EDITON		PROJECT NUMBER: [CA-15-1044] SHEET TITLE: TITLE SHEET SHEET SIZE: ADDUTC
ARCHITECT [company name] [address] [chone] LICENSED ARCHITECT: CA REG# LICENSED ARCHITECT: CA REG# LICENSED ARCHITECT: CA REG# [chone] LICENSED ARCHITECT: CA REG# [chone] [chone] LICENSED ARCHITECT: CA REG# [chone] [chone] LICENSED ARCHITECT: CA REG# [chone] [chone] LICENSED ARCHITECT: CA REG# [chone]	GEOTECHNICAL ENGR. [company name] [address] [chv] [state] [zp] [phone] LICENSED ENGINEER: CA PE REG C EXPIRATION: xolxolxoox ELECTRICAL ENGINEER [chv] [state] [zp] [phone] [chv] [state] [zp] [phone]	PROJECT DESCRIPTION SYSTEM SIZE (DC) 280.8 kW SYSTEM SIZE (AC) 240.0 kW MODULE TYPE (#9.1 JUNCEDIGON F SERIES F32582D.3Y, 329W MODULES) INVERTER 1 (#9.1 JUNCEDIGON F SERIES F32582D.3Y, 329W MODULES) INVERTER 2 N/A INVERTER 3 N/A TRANSFORMER 1 N/A LATITUDE/LONGITUDE 35.609444*/-120.658811* AZIMUTH 29.76* TIL 2************************************	TITLE 19 C.C.R. PUBLIC SAFETY, STATE FIRE MARSHAL REGULATIONS PARTIAL LIST OF APPLICABLE STANDARDS: NIFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2019 EDITION NIFPA 13 AUTOMATIC SPRINKLERS SYSTEM 2019 EDITION NIFPA 14 OF OFFICIAL SYSTEMS 2002 EDITION NIFPA 17 OFFICIAL SYSTEMS 2002 EDITION NIFPA 20 STATIONARY PUMPE 2007 EDITION NIFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NIFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NIFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NIFPA 201 CLEAN AGENT FIRE EXTINGUISHING SYSTEMS 2008 EDITION NIFPA 201 CLEAN AGENT FIRE STANDARDS 1. THIS PROJECT SHOULD COMPLY WITH THE 2013 EDITION OF THE CALIFORNIA BULLIAN BASEFTY COOL CALIFORNIA HEALT HAN BASEFTY COOL SATER EVIEW AND APPROVAL OF PROJECT CODE COMPLIANCE WILL BE DETERMINED BY: DIVISION OF STATE ARCHITECT		24 × 39° (610 × 914) 3 → 1 1 → 1
CARPENSINEER CARPERED CARPINATION: xxx0xx0xx0xx	CONTRACTOR'S LICENSE:	TILT T T T T T T T T T T T T	ADDITIONAL DOCUMENTS SUNGROW SGGKU-M INVERTER INSTALLATION MANUAL SUNDEDISON PV MODULE INSTALLATION MANUAL STRUCTURAL CALCULATIONS GEOTECH REPORT		A APROVED BY: 07.15-2016 PRAVIN BY: VB ENGINEER: AF APPROVED BY: AF PROJECT PHASE: 30% DESIGN SCALE: AS NOTED SHEET NO: G-001

Agenda Item 2

SunEdison (C), 2015 SUN EDBON, LLC AND ITS AFFLIATES, ALL ROHTS RESERVED 600 CLIPPER DRIVE BELMONT, CA 94002 (650) 453-5600 www.sunedison.com STAMP CITY OF PASO ROBLES 1860 CRESTON ROAD, PASO ROBLES, CA, 93446 SHERWOOD PARK 1 UNDER CANOPY A-201 SCALE: NTS 2 ISOMETRIC VIEW A-201 SCALE: NTS PROJECT NUMBER [CA-15-1044] SHEET TITLE: ARCHITECTURAL RENDERINGS SIZE ARCH "D" 24" X 36" (610 x 914) 0 1/2 1" C:\Users\dmeyer\Box Sync\DG Architectural Renderings.dwg HIS DRAWING IS THE PROPERTY OF SUNEDISO C. THIS INFORMATION IS CONFIDENTIAL AND IS D BE USED ONLY IN CONNECTION WITH WORK ESCRIBED BY SUNEDISON, LLC. NO PART IS TO EDISCLOSED TO OTHERS WITHOUT WRITTEN NO. REVISION 1 CITY COMMENTS DATE INIT. 11-10-16 DRM đ DATE: DRAWN BY: ENGINEER: 5:59 PM AF APPROVED BY: AF 11/10/2016 PROJECT PHASE: 30% DESIGN 4 ISOMETRIC VIEW SCALE: NTS 3 ISOMETRIC VIEW A-201 SCALE: NTS SCALE: SHEET NOTES ***** SHEET NO .: RENDERINGS ARE STRUCTURALLY ACCURATE BUT DO NOT REFLECT FINAL FINISH OF THE STRUCTURE. A-201

Exhibit B - Development Plans

1044] 15--[c4-

8

4

5

ē

Agenda Item 2

c:\Use

Exhibit B - Development Plans

5	1	2 3	4	5 6	
3	ELECTRICAL NOTES FOR NEW PHOTOVOLTAIC	23. USE MEYERS(OR APPROVED EQUIPMENT) HUB LISTED TO PROVIDE MOISTURE PROTECTION FOR CONDUIT	DISCONNECTING MEANS:	GENERAL NOTES FOR GRID TIE PHOTOVOLTAIC	(SunEdison
3	SYSTEM:	ENTRANCES IN ALL APPLICABLE LOCATIONS AS REQUIRED BY NEC 314.15.	1. MEANS SHALL BE PROVIDED TO DISCONNECT ALL CURRENT CARRYING CONDUCTORS OF THE	INVERTERS:	Sumbanoon
1	1. THIS PROPOSED SOLAR ELECTRIC SYSTEM IS INTENDED TO OPERATE IN PARALLEL WITH POWER RECEIVED FROM THE UTILITY SERVICE PROVIDER.	24. PROTECT WIRE FROM SHARP EDGES WITH UV RATED SPIRAL WRAP, EDGE GUARD, OR SPLIT LOOM.	2 WHERE A CIRCUIT GROUNDING CONNECTION IS NOT DESIGNED TO BE AUTOMATICALLY INTERRUPTED AS	1. REFER TO EQUIPMENT INSTALLATION MANUAL.	(C), 3015 SUN EDISON, LLC AND ITS AFFLIATES, ALL RIGHTS RESERVED
ē	2. THE INVERTER FOR THE PROPOSED SOLAR ELECTRIC SYSTEM SHALL BE IDENTIFIED FOR USE IN SOL	 MODULE LEAD CONNECTORS SHALL BE INSTALLED SUCH THAT THEY ARE EASILY ACCESSIBLE AND PROTECTED FROM EXPOSURE TO DIRECT SUNLIGHT OR RAIN. THEY SHALL NOT BE INSTALLED WITHIN THINK, CONNETTOR MODULE CARE. 	PART OF THE GROUND-FAULT PROTECTION SYSTEM REQUIRED BY NEC 690.5, A SWITCH OR CIRCUIT BREAKER LISED AS A DISCONFECTING MEANS SHALL NOT HAVE A POLE IN THE GROUNDED CONDUCTOR		BELMONT, CA 94002
	PHOTOVOLTAIC SYSTEMS. ALL EQUIPMENT SHALL BE UL APPROVED.	26 THE STRING SOURCE CIRCUIT WIRING NEEDS TO BE SUPPORTED ADEQUATELY IN LENGTHS NOT TO	 THE GROUNDED CONDUCTOR MAY HAVE A BOLTED OR TERMINAL DISCONNECTING MEANS TO ALLOW MAINTENANCE OR TROUBLESHOOTING BY QUALIFIED PERSONNEL. 		(650) 453-5600 www.sunedison.com
5	 THIS SYSTEM IS INTENDED TO CONNECT TO THE EXISTING FACILITY POWER SYSTEM AT A SINGLE PO POINT OF COMMON COUPLING (POCC). THIS CONNECTION SHALL BE IN COMPLIANCE WITH THE NEC 	NT, EXCEED 24". THE MODULE TO MODULE INTERCONNECTION LEADS NEED TO BE SUPPORTED AT A MINIMUM OF 12" FROM THE LEQUAND THE MODULE TO MODULE CONNECTION POINT	4. UNLESS DISCONNECT IS SERVICING A LINE-SIDE TAP, THE DISCONNECTING MEANS SHALL NOT BE		F
2	ARTICLE 705.12 POINT OF CONNECTION."	27. POLARIS TAPS AND BLOCKS ARE NOT TO BE USED TO CONNECT CURRENT CARRYING CONDUCTORS.	REQUIRED TO BE SUITABLE AS SERVICE EQUIPMENT AND SHALL BE RATED IN ACCORDANCE WITH NEC 690.17.		
LAK AK	ISOLATION.	28. MODULE TO SOURCE CIRCUIT CONNECTORS MUST BE OF THE SAME MAKE AND MODEL AS THE MODULE	5. EQUIPMENT SUCH AS PHOTOVOLTAIC SOURCE CIRCUITS, OVER CURRENT DEVICES, AND BLOCKING DIODES STALL BE DEDAUTED ON THE DIODOVOLTAIC SIDE OF THE DIOTOVOLTAIC DISCONNECTING		
3	 ALL DISCONNECTING COMBINERS SHALL BE SECURED FROM UNAUTHORIZED/UNQUALIFIED PERSONN BY LOCK OR LOCATION 	EL TO MODULE CONNECTORS. THE CONNECTION TO SOURCE CIRCUITS MUST BE PER THE MODULE MANUFACTURER AND CONNECTOR MANUFACTURER INSTRUCTIONS. CONTRACTOR TO VERIFY THAT THE	MEANS.		
2 I	6. ALL DISCONNECTING COMBINERS, PULL/SPLICE BOXES, AND ENCLOSURES SHALL BE LISTED FOR ITS	20 HOMEDIN STORY WIDEN TO BE SUDDOPTED IN INTERVALS NOT TO EXCEED 21 AND WITHIN 122 OF ALL	 MEANS SHALL BE PROVIDED TO DISCONNECT EQUIPMENT SUCH AS INVERTERS, BATTERIES, CHARGE CONTROLLERS, AND THE LIKE FROM ALL UNGROUNDED CONDUCTORS OF ALL SOURCES. IF THE 		
۲,	PURPOSE. 7 EQUIDMENT CHALL BE INSTALLED IN A SECURE ADEA	TERMINATIONS.	EQUIPMENT IS ENERGIZED FROM MORE THAN ONE SOURCE, THE DISCONNECTING MEANS SHALL BE GROUPED AND IDENTIFIED.		
Ŧ	8. CONDUITS AND CABLES SHALL NOT ENTER THE TOP OR SIDES OF ANY OUTDOOR ENCLOSURE ABOVE	 PV WIRE HARNESSES SHALL NOT BE USED. CONDUCTORS SHALL BE PARALLELED AT COMBINER BOXES OR STRING INVERTERS ONLY. 	7. A SINGLE DISCONNECTING MEANS SHALL BE PERMITTED FOR THE COMBINED AC OUTPUT OF ONE OR		STAMP:
È	ELECTRIC/ELECTRONIC EQUIPMENT WITHOUT WRITTEN APPROVAL FROM SUNEDISON PROJECT ENGINEER.	31. ALL EMT SHALL USE LISTED AND APPROVED RAIN TIGHT FITTINGS WHEN INSTALLED OUTDOORS OR IN A	MORE INVERTERS IN AN INTERACTIVE SYSTEM, PROVIDED EACH INVERTER ASSOCIATED WITH THE DISCONNECT HAS ITS OWN INTERNAL AC DISCONNECT.		
<u></u>	9. ALL METALLIC EXPANSION FITTINGS SHALL HAVE INTERNAL OR EXTERNAL BONDING TO ENSURE	WEI LUCATION. 32. OUTDOOR FLECTRICAL CONNECTIONS SHALL BE STAINLESS STEEL HARDWARE ONLY	8. DISCONNECTING MEANS SHALL BE PROVIDED TO DISCONNECT A FUSE FROM ALL SOURCES OF SUPPLY IF THE FUSE IS ENERGIZED FROM BOTH DIRECTIONS AND IS ACCESSIBLE TO OTHER THAN OUALIFIED.		
5	CONTINUITY.		PERSONS. SUCH A FUSE IN A PHOTOVOLTAIC SOURCE CIRCUIT SHALL BE CAPABLE OF BEING DISCONNECTED INDEPENDENTLY OF FUSES IN OTHER PHOTOVOLTAIC SOURCE CIRCUITS.		
ξļ	WIRING AND WIRING METHODS:	THE ELECTRICAL CONTRACTOR CHAIL CONSIDER THE MEATHERING OF FOLIDMENT OVER THE AND	9. ALL DISCONNECTS AND COMBINERS SHALL BE SECURED FROM UNAUTHORIZED AND UNQUALIFIED		
₹	ALL WIRING METHODS AND INSTALLATION PRACTICES SHALL CONFORM TO THE NATIONAL ELECTRIC COD LOCAL STATE CODES AND OTHER APPLICABLE LOCAL CODES	 THE ELECTRICAL CONTRACTOR SHALL CONSIDER THE WEATHERING OF EQUIPMENT OVER TIME AND ELIMINATE THE POSSIBILITY OF DEGRADATION DUE TO CORROSION, WATER ENTRY AND UV EXPOSURE. AS A DESULT THE USE OF UNIVERSITY OF SIMILAR MOUNTING SYSTEMS IS DEDUIDED TO MOUNT 	PERSONNEL BY EITHER LOCK OR LOCATION.		
	1	ENCLOSURES, PULL BOXES, LOAD CENTERS, FUSE BOXES, OR OTHER EQUIPMENT.	REQUIRED SAFETY SIGNS AND LABELS:		
Ĕ	ALL EXPOSED CABLES, SUCH AS MODULE LEADS SHALL BE SECURED WITH MECHANICAL OR OTHER APPROVED SUN-LIGHT RESISTANT MEANS. THE USE OF PLASTIC ZIP THESIS NOT AN APPROVED METH TO DEPORT OF A D	 ALL NEMA 4 BOXES SHALL BE EQUIPPED WITH LISTED DRAIN PLUGS INSTALLED TO ALLOW WATER TO DRAIN. ANY MODIFICATION TO AS-MANUFACTURED EQUIPMENT SHOULD BE DONE IN SUCH A WAY AS TO 	REQUIRED SAFETY SIGNS AND LABELS SHALL BE ETCHED PLACARDS PERMANENTLY ATTACHED BY ADHESIVE, OR OTHER MECHANICAL MEANS. LABELS SHALL COMPLY WITH ARTICLE 690 OF THE NECON OTHER ADDIFACHE STATE ADD LOCAL CODES. SEE LABELS SHALL COMPLY WITH ARTICLE 60D OF THE DEFORMATION		
8	GOUT OR OWNER OF STRUCTORE, HESE ARE OWNER FERMINE OF SUPPLEMENTAL GROUPING OR BUNDLING CONDUCTORS INSDE OF EQUIPMENT. HEYCO SUBRUNNER PV SPECIFIC STAINLESS STEEL CLIPS AND HEYCO SUBRUNDLER VINVL JACKETED STEEL CABLES THES OR AN	BOUNTAIN ALL LISTED RATINGS. 3. ALL NEMA 3 BOXES SHALL BE EQUIPPED WITH A WEEP HOLE OR LISTED DRAIN PLUCS INSTALLED TO	WEAR PERSONAL PROTECTIVE EQUIPMENT(PPE) APPROPRIATE FOR THE HAZARD: INSULATED GLOVES WITH		
ź	APPROVED EQUAL ARE ALLOWED FOR USE IN THIS APPLICATION.	ALLOW WATER TO DRAIN.	PROTECTORS, INSULATED MATS AND TOOLS. 1. ANY SWITCH, FUSES, OR CIRCUIT BREAKERS THAT CAN BE ENERGIZED IN EITHER DIRECTION SHALL RF		
0 4	WIRE COLOR SPECIFICATIONS: AC WIRE COLOR CHART	4. ALL OUTDOOR ENCLOSURES REQUIRE AN APPROVED MEANS OF DRAINAGE AND VENTILATION. 5. ALL ELECTRICAL CONDUIT FOURPMENT AND COMPONENTS MUST BE ADEQUATELY PROTECTED FROM	LABELED AS FOLLOWS:		X
5	AC CONDUCTORS	DAMAGE AND VANDALISM BY THE USE OF BOLLARDS, SHIELDS, GUARDS OR OTHER ACCEPTABLE MEANS.	WARNEYG: ELECTRICAL SHOCK HAZARD DO NOT TOUCH TERMINALS. TERMINALS ON BOTH THE LINE AND LOAD SIDES MAY BE		A A
<u>è</u>	277 / 480 Volt 120 / 208 Volt Phase 4 BROWN DLACK	 ALL CIRCUIT BREAKERS INSTALLED THAT ARE SUBJECT TO REVERSE POWER FLOW SHALL BE LISTED AND LABELED AS BACKFEED COMPATIBLE. 	ENERGIZED IN THE OPEN POSITION 2 THIS DEOTONOLTAIC SYSTEM WILL BE EQUIDDED WITH DC DISCONNECTING COMPARING WITH DE		ପ ଅନ୍ତର୍ଦ୍ଧ
Š	Phase B ORANGE RED	ALUMINUM CONDUCTOR INSTALLATION NOTES:	2. THIS PROTOVOLTAR STSTEM WILL BE EQUIPTED WITH DC DISCONNECTING COMBINERS WHICH WILL BE LABELED AS FOLLOWS:		
00 les	Phase C YELLOW BLUE Grounded Conductor GRAY or WHITE WHITE	 MINIMUM WIRE SIZE FOR CURRENT CARRYING CONDUCTORS WHEN IMPLEMENTING ALUMINUM AS A CONDUCTOR SHALL BE 1/0 AWG STRANDED. COMPACT ELECTRICAL CRADE AA-8000 SERIES ALLOY. 	PHOTOVOLTAIC DISCONNECTING COMBINERS		
8	Grounding Conductor GREEN or BARE GREEN or BARE	2. ALUMINUM POWER CABLE, WIRE CONNECTORS, AND INSULATING AND CODING TAPE MANUFACTURERS	 THIS PHOTOVOLTAIC SYSTEM WILL BE EQUIPPED WITH AN AC DISCONNECT WHICH WILL BE LABELED AS FOLLOWS: 		I E E E E E E E E E E E E E E E E E E E
2	Grounding Electrode Conductor GREEN W/ ORANGE GREEN W/ ORANGE	3. WHERE BOLTED CONNECTIONS ARE NOT POSSIBLE, MECHANICAL SCREW STYLE LUGS AND	PHOTOVOLTAIC DISCONNECTING MEANS		
ŝ	DC WIRE COLOR CHART DC CONDUCTORS	TERMINATIONS ARE APPROVED ONLY WHEN USED IN CONJUNCTION WITH A LISTED COPPER PIGTAIL COMPRESSION ADAPTOR (SOLID CORE PIN ADAPTERS ARE NOT ALLOWED).	A.C. DISCONNECT A MADKING SECTEMING THE DEGTOVOLTAGE DOWED SOLIDGE DATED AS EQUIDES SHALL BE DROWIDED.		
ŝ	SYSTEM TYPE POSITIVE (+) NEGATIVE (-) GROUND	4. USE OF A 'ONE-SHOT' CRIMPER OR 'DIE-LESS CRIMPERS' WILL NOT BE ALLOWED.	4. A MARKING SPECIFIEND THE PROTOKOLDAC POWER SOURCE RATED AS POLLOWS SHALL BE PROVIDED AT AN ACCESSIBLE LOCATION AT THE DISCONNECTION MEANS FOR THE POWER SOURCE:		
olec	Ungrounded (Floating Systems) RED BLACK Positive Grounded Systems WHITE or GRAY BLACK GREEN or BARE	 COMPRESSION STYLE LUGS AND TERMINATIONS SHALL BE RATED FOR THE MAXIMUM DC AND AC VOLTAGE OF THE SYSTEM. 	OPERATING CURRENT OPERATING VOLTAGE MAXIMUM SYSTEM VOLTAGE		
1 S	Negative Grounded Systems RED WHITE or GRAY	5.1. MUST BE PRE-FILLED WITH OXIDE INHIBITOR.	SHORT CIRCUIT CURRENT COMBINER		
atio	NOTE: CONTRACTOR IS REQUIRED TO SUBMIT WIRE SPECIFICATIONS (INSULATION TYPE, COLOR, & CONDUCTOR MATERIAL) TO SUNEDISON FOR APPROVAL PRIOR TO PROCUREMENT/INSTALLATION.	 WHE STRIPPING AND BRUSHING OF CONDUCTOR IN ACCORDANCE WITH VENDOR SPECS IS REQUIRED IMMEDIATELY PRIOR TO LUG INSTALLATION. 	 ANY JUNCTION BOX, COMBINER BOX, DISCONNECT, AND DEVICE WHERE ENERGIZED UNGROUNDED DC CIRCUITS MAY BE EXPOSED DURING SERVICE: 		
obe	3. PV STRING HOME RUNS SHALL BE LABELED ON BOTH ENDS, AT ARRAY AND AT COMBINER. COMBINER OUTPUT CONDUCTORS SHALL BE LABELED AT BOTH ENDS. AT COMBINER AND AT INSCOMPLET	5.3. OXIDE INHIBITOR MUST BE APPLIED TO EXPOSED CONDUCTOR IMMEDIATELY AFTER STRIPPING AND BRUSHING AND IMMEDIATELY PRIOR TO INSTALLATION OF THE LUG.	WARNING: ELECTRICAL SHOCK HAZARD		PROJECT NUMBER:
ortal	4. LIQUID TIGHT FLEXIBLE METAL CONDUIT IS GENERALLY SUITABLE FOR INSTALLATION IN WET AND DR	5.4. USE COMPRESSION TOOL LISTED FOR USE WITH SELECTED COMPRESSION CONNECTOR. 5.5. A MINIMUM 9" LENGTH OF COLD OR HEAT SHRINK WITH A VOLTAGE RATING EQUAL TO THE	THE CONDUCTORS OF THIS PHOTOVOLTAIC SYSTEM ARE UNGROUND AND MAY BE ENERGIZED		
ē	LOCATIONS. SHOULD IT BE EMPLOYED, SUPPORTS WILL BE NO MORE 12 INCHES FROM BOXES (JUNC BOX, CABINETS, OR CONDUIT FITTING) AND NO MORE THAN 54 INCHES APART (NEC 350.30).	ION CONDUCTOR SHALL BE APPLIED TO COVER THE CONNECTION BETWEEN CRMP AND THE CONDUCTOR BEGINNING AT THE STRAIGHT SECTION OF THE CRMP.	MARKINGS:	ELECTRICAL SYMBOLS	SHEET ITTLE:
ren	 THE PHOTOVOLTAIC SOURCE CIRCUITS AND PHOTOVOLTAIC OUTPUT CIRCUITS OF THIS PROPOSED SOLAR SYSTEM SHALL NOT BE CONTAINED IN THE SAME RACEWAY, CABLE TRAY, CABLE, OUTLET BOD UNCETTON HOW ON EASIER AND REPORTING AS PERFORDED ON BRANCH CIRCUITS OF CHURCH SOURCE IN LISS 	5.6. ALL CONNECTORS AND CORRESPONDING CRIMPING TOOLS SHALL BE UL LISTED FOR THEIR SPECIFIC APPLICATION.	 ALL INTERACTIVE SYSTEM POINTS OF INTERCONNECTION WITH OTHER SOURCES SHALL BE MARKED AT AN ACCESSIBLE LOCATION AT THE DISCONNECTION MEANS. 		- ELECTRICAL NOTES
ē	CONDUCTORS OF THE DIFFERENT SYSTEMS ARE SEPARATED BY A PARTITION OF ARE CONNECTED TOGETHER.	 INSULATING AND COLOR CODING TAPE SHALL BE PREMIUM GRADE PRESSURE SENSITIVE VINVL, HEAT/COLD/MOSTURES/UNLIGHT/ RESISTANT. INSULATING TAPE SHALL BE BLACK AND COLOR CODING 	2. A PERMANENT ETCHED PLAQUE OR DIRECTORY SHALL BE PROVIDED IDENTIFYING THE LOCATION OF THE SERVICE DISCONNECTION MEANS AND THE PHOTOVOLTAIC SYSTEM DISCONNECTION MEANS, IF NOT	1KANSFORMER	
l a	6. UNLESS MARKED AS UV RESISTANT, PVC IS NOT APPROVED FOR INSTALLATION IN LOCATIONS SUBJE TO DIRECT SUNLIGHT AND SHALL NOT BE EMPLOYED IN ANY SUCH LOCATION.	TED 7. FOR ALUMINUM MV CONDUCTORS, WHERE USED, THE GUIDELINES IN THIS SECTION PLUS GENERAL	3. ALL REQUIRED EQUIPMENT SHALL BE ULLISTED AND LABELED ACCORDINGLY.	°∼• SWITCH	SHEET SIZE: ARCH "D" 24" X 26" (210 + 014)
Š	 LONG STRAIGHT EXPOSED METAL CONDUIT (RMC, GRC, EMT) RUNS, 100 FEET OR MORE, SHALL HAVE EVENNSION EPTIMICS INSTALLED BER NEC 200 7(0). EVENNSION EPTIMICS SHALL ALSO BE LISED MUEL 	REQUIREMENTS FOR MV CONDUCTOR INSTALLATION SHALL APPLY. BIRECT LANDING OF ALLIMINUM CONDUCTORS IS ONLY ALLOWED TO REFAKERS WHICH ARE	 ALL PULL BOXES SHOULD BE PERMANENTLY MARKED WITH EITHER "ELECTRIC" OR "COMMUNICATION" DEPENDING ON THE APPLICATION. PER NEC 110 75(E) 		24 X 36 (610 X 914)
	CONDUIT SPANS AN EXPANSION JOINT.	SPECIFICALLY RATED FOR ALUMINUM CONDUCTORS.		INVERTER	THIS DRAWING IS THE PROPERTY OF SUNEDISON, LLC. THIS INFORMATION IS CONFIDENTIAL AND IS
λ λ	O. FUSES AND WIRES SUBJECT TO TRANSPORMENTINFUSH CURRENT SHALL BE SIZED ACCORDINGLY. O. ALL DC MATERIALS SHALL BE ULLISTED FOR 1000V DC.	SEE ELECTRICAL DIACRAMAND ELECTRICAL DETAILS FOR MORE CRAINDING NEORMATION		FUSE.	TO BE USED ONLY IN CONNECTION WITH WORK DESCRIBED BY SUNEDISON, LLC. NO PART IS TO BE DISCLOSED TO OTHERS WITHOUT WOITTEN
in l	10. WHEN TRANSITIONING UNDERGROUND PVC CONDUIT TO ABOVE GROUND RMC, IMC OR EMT CONDUIT	USE 1. ONLY ONE CONNECTION TO DC CIRCUITS AND ONE CONNECTION TO AC CIRCUITS WILL BE USED FOR			PERMISSION FROM SUNEDISON, LLC.
leyer	METALLIC CONDUIT. AN EXPANSION JOINT SHALL BE USED IN THE TRANSITION TO ABOVE GROUND CONDUIT WHERE REQUIRED BY NEC 300.5(J).	SYSTEM GROUNDING (NEC 600/22) (REFERENCED TO THE SAME POINT). 2. FOURMENT GROUNDING CONDUCTORS AND SYSTEM CROUNDING CONDUCTORS WILL HAVE AS SHOPE A		◦ ◦− SURGE ARRESTOR	NO. REVISION DATE INIT.
5	11. ANY METAL SHAVINGS RESULTING FROM SITE WORK SHALL BE CLEANED FROM ENCLOSURE INTERIO	DISTANCE TO GROUND AS POSSIBLE AND A MINIMUM NUMBER OF TURNS.		600A NON-LOAD BREAK FLBOW	1 CITY COMMENTS 11-10-16 DRM
ES.d.	10F SURFACES OF ENCLOSURE, ROOF SURFACE, AND ANY ADDITIONAL AREAS WHERE OXIDATION OF CONDUCTIVE METAL SHAVINGS MAY CAUSE RUST, ELECTRICAL SHORT CIRCUIT OR OTHER DAMAGE.	 NUN-CURRENT CARRYING METAL PARTS SHALL BE CHECKED FOR PROPER GROUNDING; NOTING THAT TERMINAL LUCS BOLTED ON AN ENCLOSURE'S FINISHED SURFACE MAY BE INSULATED BECAUSE OF PARTEENISM. DAINTEDINGLA IT POINT OF CONTACT CHAIL BE PROPERTY DEDUCING DAINTERNISM. 			
5 b	 CONDUTS LONGER THAN 200 FT WITH NEGATIVE SLOPE TOWARD ELECTRICAL EQUIPMENT SHALL HA PULL BOX OR VAULT ADJACENT TO THE ENTRY POINT INTO THE ELECTRICAL EQUIPMENT. 	E A . RACKING COMPONENTS AND STRUCTURAL SUPPORTS MUST BE ELECTRICALLY BONDED TOGETHER BY AN		<u>TR-31</u> TRANSFORMER NUMBER	
	13. WHEN TRANSITIONING FROM FREE AIR TO CONDUCTORS IN CONDUIT A LISTED FITTING SHALL BE USED TO PREVENT THE ENTRY OF MOISTURE.	ACCEPTABLE MEANS. 5. MODULES SHALL BE GROUNDED WITH EQUIPMENT GROUNDING METHODS APPROVED RV THF	POINT OF CONNECTION TRANSFORMER	SC1	
	14. L AND T CONDUIT BODIES SHALL NOT BE USED.	MANUFACTURER WITH A MEANS OF BONDING LISTED FOR THIS PURPOSE.	PC_<##> XFR_##	SECTIONALIZED CABINET NUMBER	
	15. ALL AC AND DC COPPER TERMINATION(S) SHALL HAVE KOPR SHIELD OR EQUIVALENT APPLIED.	ARRANCED THAT REMOVAL OF A MODULE OR A PANEL FROM THE PHOTOVOLTAIC SOURCE CIRCUIT DOES NOT INTERRUPT A GROUNDED CONDUCTOR TO ANOTHER PHOTOVOLTAIC SOURCE CIRCUIT DOES	PC_01 XFR_01	© REFERS TO CABLE SCHEDULE.	
	10. INCOMENTATION OF THE PREPARED AT 1000 VDC FOR ALL AC LIRCUITS 480 V OR BELOW AND DK CIRCUITS 600 V OR BELOW. MEGGER TESTING WILL BE PREFORMED AT 1500 VDC FOR DC CIRCUITS P 1000 VDC SYSTEMS. A MINIMUM OF 250 MEGACHAS RESISTANCE TO GROUND IS REQUIRED. DO NOT	MODULES INTERCONNECTED AS SYSTEMS RATED AT 50 VOLTS OR LESS WITH OR WITHOUT BLOCKING DIODES, AND HAVING A SINGLE OVER CURRENT DEVICE SHALL BE CONSIDERED AS A SINGLE SOURCE CIRCUIT.	NAME TRANSFORMER		
ş	MEGGER THE SOLAR MODULES AS DAMAGE WOULD LIKELY RESULT. 17. BENDS SHALL NOT DAMAGE THE RACEWAY OR SIGNIFICANTLY CHANGE THE INTERNAL DIAMETER OF	 GROUNDING SYSTEM COMPONENTS SHALL BE LISTED FOR THEIR PURPOSE, INCLUDING BUT NOT LIMITED SEO OPOUNTS PARSA OPOUNTS IN USA OPOUNTS	IDENTIFIER	(WV103) MV CABLE IDENTIFICATION NUMBER	DATE: 20-07-2016
-	RACEWAY PER TABLE 2 OF THE NEC.	TO GROUND RODS, GROUNDING LUGS, GROUNDING CLAMPS, ETC. 8. WHERE USED, GROUND LUGS SHALL BE RATED FOR DIRECT BURIAL (DB RATED). CONTRACTOR IN TO	STRING INVESTOR	△ DELTA CONNECTION	DRAWN BY: VB ENGINEER: AF
6:2	300.19. Some set compactores in ventional company's IN ACCONDANCE WITH THE REQUIREMENTS OF NEC	SUPPLY DOCUMENTATION PROVING THIS DURING PRODUCT SUBMITTALS.	STD cinvotor#5, ## DN/ ##		A APPROVED BY: AF
2016	19. CONNECTORS TO BE TORQUED PER DEVICE LISTING, OR MANUFACTURERS RECOMMENDATIONS. CONNECTORS ARE TO BE MARKED WITH PERMANENT MARKING PAINT, AFTER TORQUEING.	10. ALL RACEWAYS AND ENCLOSURES WILL REQUIRE A PHYSICAL CONNECTION TO THE GEC CONTAINED		Y WYE CONNECTION	PROJECT PHASE: 30% DESIGN
10	20. ALL BARE CU WIRES SHALL BE INSTALLED TO NOT COME INTO CONTACT WITH DISSIMILAR METALS .		STRING		SCALE: NO CONT
È	 SPLICES/CONBCTORS SHALL BE INSULATED AND WILL REQUIRE PROJECT ENGINEER APPROVAL UI LISTED ELECTRICAL TAPE ALONE IS NOT SUITABLE AS THE ONLY INSULATION MEANS. FOLLOW MANUFACTURERS INSTRUCTIONS FOR INSTALLATION AND APPLICATION OF INSULATION PRODUCT. 	COUND FAULT PROTECTION: PHOTOVOLTAIC INVERTERS SHALL BE EQUIPPED WITH DC CROIND FAILT PROTECTION TO REDUCE FIRE	INVERTER IDENTIFIER		NO SCALE SHEET NO.:
ëdi	22. ALTERNATE THE NAME WILL BE CHIEFD OF DUTING AND ANTERPORT OF DUTING AND ANTERPORT	HAZARDS. INVERTERS ARE ALSO EQUIPPED WITH ANTI-ISLANDING CIRCUITRY.	IDENTIFIER		E 001
Print	ALLEBANALE. THIS NOTE WILL BE SUPERCEDED BY ANY INVERTER SPECIFICATIONS REQUIRING LV AC WIRE TO MEET HIGHER VOLTAGE OR INSULATION STANDARDS.				
- 6	CANOPY DSA TEMPLATE RELEASE 1.2			Revision #17 12/03/20	015

nio	1 2 3	4 5 6	
2 MEI	GENERAL MEDIUM VOLTAGE NOTES:	 ALL MECHANICAL CONNECTIONS OTHER THAN ELBOW CONNECTORS SHALL BE MADE USING ULLISTED TIM-PLATED COPPER (INCLIMPERENTIAL COMPRESSION LIGS, LIGS SHALL BE LONG, BARREL WITH WITH USING DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DEURING DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DE DOUBLETER DEURING UND DE DEURING MEDIUM UND LONGER DE DOUBLETER DE DOUBLETER DEURING DE DEURING DE DOUBLETER DE DOUBLET DE DOUBLETER DE DOUBLET DE DOUBLETER DE DOUBLET DE D	SunEdison
00-1	2. POWER CABLE, ELBOW, AND M.V. TERMINATION DRAINS SHALL BE INSTALLED IN A MANNER THAT WILL	NEMA INVO HOLE DIBLIENCE, BURGUT HILLOS MODEL TAC DRE EQUIVALENT CONNECTED WITH HICH STRENCTH SILCON BRONZE BUS BOLTS, NUTS AND LOCK WASHERS. LLIGS TO MATCH CONDUCTOR TYPE.	(C), 2015 SUN EDISON, LLC AND ITS AFFILIATES, ALL RIGHTS RESERVED
rical /	ALCOW FOR THE REMOVAL, STANDING OFF, AND/OR LANDING OFF ELEROWS WITH MINIMUM BENDING RADIUS PER NEC 300.34.	8. VERIFY PROPER TORQUE OF ALL BOLTED CONNECTIONS USING A CALIBRATED TORQUE WRENCH AND	600 CLIPPER DRIVE BELMONT, CA 94002
Electr	TAPE SHIELD ADAPTER KITS ARE TO BE USED WITH POWER CABLE THAT HAS TAPE SHIELDING. THE MERTINING TAGE SYSTEM IS DESIGNED TO BE A fry york 1.30kies 1.30kies 1.00kies 1	MARK EACH BULT HEAD TO INDICATE VERPICATION IS COMPLETE.	(650) 453-5600 www.sunedison.com
5.0	 The metadomined rate of station is described to be a function, strike Production, EFFECTIVELY GROUNDED SYSTEM WHETHER CONNECTED TO THE UTILITY OR ISOLATED FROM IT. 	CLEAN AND LOBRANCE RELIGIONBLEAK AND DEADBREAK AND DEADBREAK DUSING SURFACES PER MANUFACTORER'S INSTRUCTIONS BEFORE FINAL CONNECTION.	
PARK	A LL MEDIUM VOLTAGE KONK SWALL COMPLY WITH THE LATEST EDITION OF ANSI C2 - NATIONAL ELECTRICAL SAFETY CODE (NESC) M EMILIARY OF TAGE CAR ES:	10. MOINT FAULT NORCHORS SUCH TAAT NORCHORS WINDOW IS BEADAILY VISIBLE WITHOUT THEN RED TO ENTER THE CABLE COMPAREMENT OR MOVE CONDUCTORS OR OTHER COMPONENTS. LABEL FAULT NDRCHORS WITH CRECUT INFERCIANA USING ENCOUCH PREVALE LABEL.	
RWOOD	6.1. WHERE WEDIUM VOLTAGE CABLES ARE INSTALLED ALONG ACCESS ROADS, THEY SHALL BE DIRECT BURIED.	11. ALL 600 VOLT CLASS AC WIENG SHALL BE COPPER WIRE, TYPE THH/VTH/WN.2 RATED AT 90 DEGREES C, AND RATED FOR 600Y, OR APPROVED EQUAL	
R	 SHOP DRAVINGS SHALL BE SUBMITTED FOR ENSINEER REVIEW AND APPROVED PRIOR TO FABRICATION OR INSTALLATION OF THE FOLLOWING EQUIPMENT. 		
044]	7.1 UUULH-UT(DIS OF TESTING ASSNC)	EQUIPMENT: EQUIPMENT AD COMPONENTS SHALL BE LISTED AND LABELED BY A NATIONALLY-RECOGNIZED TESTING	STAMP:
5-10	MEDUM VOLIAGE SWITCHGEARSECTIONALIZING CABINET MV SWITCH LOUVING CABINET TO AND UNC.	LABORATORY (NRTL) SUCH AS UL OR ETL, WHERE SUCH LISTING IS AVAILABLE FOR THE APPLICATION.	
√[CA-1	LOW YOU KNE WINNER TO TAVGORY ORY TYPE DISTRUMINING (REX) TRANSFORMER D COOMMER BOXES D CONSTRUME SUTCH	PROVIDE DAVIGER, WARNING, AND CAUTION LABLE SAS REQUIRED BY NESC, OR OSHA STANDARDS ON EQUIPMENT MICLOSTRESS LOOPS, ACCESS PLATES, AND BARRIERS AND LABLE ALL MEDIUM VOLTAGE EQUIPMENT WITH THE OPERATING VOLTAGE.	
ACAD	LOW VOLTAGE AC BREAKER LOW VOLTAGE PANELDARDS	3. DOORS PROVIDING ACCESS TO PARTS NORMALLY ENERGIZED AT OVER 600V SHALL BE PADLOCKABLE CLOSED, REMOVABLE PANELS PROVIDING ACCESS TO PARTS NORMALLY ENERGIZED AT OVER 600V	
100	7.3 CONTRACTOR (TESTING AGENCY) TO PERFORM ACCEPTANCE TESTING PER SPECIFICATION SECTION 10080.	SHALL REQUIRE TOOLS FOR REMOVAL OR BE PADLOCKABLE CLOSED.	
Park	8. ALL EQUIPMENT INCLUDING SWITCHGEAR SECTIONALIZING CABINETS, TRANSFORMERS, ETC. SHALL BE LARGE EP AN THE EPONET EVERTION TO COORDEPOND TO THE DESTRUCTION FUNDAMENT THE	MEDIUM VOLTAGE EQUIPMENT INSTALLED OUTSIDE OF FEXCES WHERE ACCESSIBLE TO THE PUBLIC SHALL COMPLY WITH NESS REQUIREMENTS FOR TAMPER PROOF CONSTRUCTION.	
rwood	DREEDON THE MOST DATABASE TO CARGE WITH OUTDOOR, REFLECTIVE, ADMESIVE LABELS, BLACK ON YELLOW, MINIMUM 2 INCH HIGH LETTERS.	EQUIPMENT SHALL BE ANCHORED TO CONCRETE PAGS OR FOLINDATIONS PER MANUFACTURERS INSTRUCTIONS USING GALVANIZED STEEL ANCHOR BLX TS INBEDIEDD IN PAD OR WITH IN INCH DEEP EPDXY ANCHORE BOLTS ANCHORE BAD STEEL ANCHORE RECOMMENDATION EPDXY INCHORE BOLTS ANCHORE BAD STEEL RECOMMENDATION	
144 She	 ALL MEDIUM VICE TAGE AD LESS SINLE EL LABELED AT EACH PRIO AT MAIACCESSEILE FORT INSIDE EQUIPMENT ENCLOSURE, WITH CIRCUIT AND PHASE DENTIFICATION CORRESPONDING TO THE DRAWINGS. LABELES SINLE LE ENGANCE. AND FALLES STREEL, CAR TWO CALCOR ENGANAVED 	 ALL OPENINGS INTO EQUIPMENT SHALL BE SEALED WITH GALVANZED STEEL PLATE OR SCREEN TO PREVENT ENTRY OF INSECTS AND RODENTS. 	RI 146
5-10	PHENDLIC, SECURED WITH UNRESISTANT WHE THES LABELS SHALL BE VISIBLE FROM OUTSIDE THE ENCLOSURE WITHOUT REACHING INSIDE OR MOVING CABLES.	7. CAULK ALONG BOTTOM PERIMETER OF EQUIPMENT MOUNTED ON CONCRETE PADS TO PREVENT WATER	DA DA
\CA−1	 ARRANGE PHASES IN SWITCHGEAR, SECTIONALIZING CABINETS, ETC., A B-C FROM LEFT TO RIGHT OR TOP TO BOTTOM AS VIEWED FROM THE FRONT. 	ENTRY BEITWEN BUTTOM OF ENALUSINE AND TOP OF CURRE TESTAB. 8. PROVIDE 12 INCHES OF CLASS 5 GRAVEL DRAINAGE BEDDING IN THE BOTTOM OF ALL BOTTOM CONDUIT	CA, CA,
obles	 VERIFY UTILITY PHASE SEQUENCE AND COORDINATE INSTALLATION OF FEEDER CONDUCTORS TO PROVIDE CORRECT PHASE SEQUENCE AT INVERTER SIDE OF STEP-UP TRANSPORMERS. 	ENTRIES TO OPEN CABLE COMPARTMENTS.	
ISO R	12. PROVIDE ARC FLASH HAZARO WARNING LABELS COMPLYING WITH ANSI 2535.4 ON ALL EQUIPMENT.	 ALCONDUCTORS SMULL BE ROUTED TO MAINTAIN ACCESS TO INDICATORS, VALVES, SAMPLE PORTS, SWITCHES, TAP CHANGES, FUSE WELLS, AND OTHER COMPONENTS AND ACCESSORIES REQUIRING OPERATOR ACCESS. 	
of Pc	LABELS SHALL BE APPLED ON BOTH INSIDE AND OUTSIDE DOORS OR BARRIERS OF OUTDOOR EQUIPMENT.	10. PLACE MICARTA NAMEPLATES WITH MINIMUM 34" HIGH LETTERS FOR DISTRIBUTION EQUIPMENT	
\City	13. ALL EQUIPMENT LABELING SHALL COMPLY WITH SUN EDISON REQUIREMENTS.	SWITCHGERK INVERTIERS, HARRSHORMERS, ETC.	R OOR
ojects'	 EQUIPMENT AND COMPONENTS SHALL BE LISTED AND LABELED BY A NATIONALLY RECOGNIZED TESTING LABORATORY (NRTL) SUCH AS UL OR ETL, WHERE SUCH LISTING IS AVAILABLE FOR THE APPLICATION. 	3R ENCLOSURES WHERE NEMA 4 IS NOT AVAILABLE.	E E
ns\Pro	 PROVIDE DANGER, WARNING, AND CAUTION LABELS AS REQUIRED BY NESC, OR OSHA STANDARDS ON EQUIPMENT EXCLOSURES, DOORS, ACCESS PLAYERS, AND BARRIERS AND LABEL ALL MEDIUM VOLTAGE EQUIPMENT WITH THE OPERATION OF TAGE. 	12. EQUIPMENT SHOLD BE PROTECTED WITH BOLLARDS OR OTHER MEANS WHEN REQUIRED TO CUNRESTRICTED VEHICULAR ACCESS.	B ¹ C SH
atic		TRANSFORMERS:	•
\Ope	CONDUITS ADM DUCTBANKS:	1. TRANSFORMERS SHALL BE SECURELY BOLTED TO THE EQUIPMENT PAD AND MADE LEVEL ANY GAPS BETWEEN THE PAD AND ABSE OF THE TRANSFORMER MUST BE SALED.	PROJECT NUMBER:
Portal	2. ALL MEDIUM VOLTAGE CONDUITS SHALL HAVE MINIMUM 60 INCH RADIUS SWEEPS EXCEPT 36 INCH	2. PROPER TORQUE SHALL BE APPLIED TO ALL BUSHINGS AS INDICATED.	SHEET TITLE:
Ind	MINIMUM RADIUS IS REQUIRED FOR VERTICAL SWEEPS UP TO EQUIPMENT.	3. PROPER LABELING REQUIRED FOR: TRANSFORMER, POWER CABLES, HIGH VOLTAGE COMPARTMENT (STATEMENT OF VOLTAGE), AND TRANSFORMER DOORS (DANGER WARNING).	MEDIUM VOLTAGE
I Inte	 and entry of a minimum of increase or a shading a more than a shading a more than a shading a	4. NEMA DRILLED LONG BARREL COMPRESSION LUGS TO BE USED FOR THE LOW VOLTAGE WIRE.	ELECTRICAL NOTES
hercia	 MAINTAIN MINIMUM 4 FOOT SPACING BETWEEN MEDIUM VOLTAGE CONDUCTORS AND POWER CIRCUITS OF THER SYSTEMS WHEN RUN PARALLEL FOR DISTANCES OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OF THE RUN OF ETHER OPPORT IN BE PUR DURLATION RECEIPTING PORTED AND ADDRESS OF OVER 10 PERCENT OPPORT OF THE RUN OF THE RUN	5. PENTABOLTS ARE TO BE USED ON BOTH SETS OF DOORS.	SHEET SIZE:
Comr	ETTINE URUGAL WILESS THE URUGANYA BENTANA ANA TANANA ANA ANA ANA ANA ANA ANA	 ALL CONDUCTORS SHALL BE ROUTED TO MAINTAIN ACCESS TO INDICATORS, VALVES, SAMPLE PORTS, SWITCHES, TAP CHANGES, FUSE WELLS, AND OTHER COMPONENTS AND ACCESSORIES REQUIRING 	ARCH "D" 24" X 36" (610 x 914)
DC/DC	 MAINTAIN ALL CONDUIT ENTRIES TO EQUIPMENT WITHIN MANUFACTURERS DESIGNATED CONDUIT ENTRY SPACE AND ARRANGE CONDUITS TO PERMIT THE MOST DIRECT ROUTING OF CABLES TO TEDMINAL CAULT TO ALL INCLUSION AND ADDIVISION OF ALL ADDIVISION AND ADDIVISION OF ALL ADDIVISION AND TEDMINAL CAULT AND ADDIVISION AND ADDIVISION AND ADDIVISION OF ALL ADDIVISION AND ADDIVISION OF ALL ADDIVISION TEDMINAL CAULT ADDIVISION AND ADDIVISION AND ADDIVISION AND ADDIVISION OF ALL ADDIVISION AND ADDIVISION ADDIVISIONAL ADDIVISIONAL ADDIVISIONALISMA ADDIVISIA ADDIVISIONALISMA ADDIVISIONALISMA ADDIVISION	OPERATOR ACCESS.	THIS DRAWING IS THE PROPERTY OF SUNEDISON,
Sync	DEVADBREAK ELBOW CONNECTORS.	7.1. FACTORY WIRING DIAGRAM IS ACCURATE 7.2. TRANSFORMER IS LEVE	TO BE USED ONLY IN CONNECTION WITH WORK DESCRIBED BY SUNEDISON, LLC. NO PART IS TO
ICAL -	6. TORS OF CONDUCT SHALL BE A MINIMUM OF A INCHESTABLY TRANSMISSION OF AUXIEST ADDRESS OF WATER. SEAL ALL CONDUITS TO PREVENT TRANSMISSION OF HUMID AIR BEVIEWEN INTERIOR AND EXTERNO OF CONDUCTS TO PREVENT TRANSMISSION OF HUMID AIR	7.3. MEDIUM & LOW VOLTAGE CONDUITS ARE SEPARATED AND UNDER THEIR OWN COMPARTMENT 7.4. LOW VOLTAGE WIRE ARE ROUTED SO THAT THERE IS ACCESS TO THE OIL DRAIN VALVE AND OIL	PERMISSION FROM SUNEDISON, LLC.
ECTR.	7. ALL CONDUITS ENTERING EQUIPMENT TO BE EQUIPPED WITH BELL ENDS TO PREVENT ABRASION.	SWIRTER PURI 7.5. LOCK OR CONICAL NUTS 7.6. Hughmade is THE PROPER LENGTH	NO. REVISION DATE INIT.
ers/d GE El	CONDUCTORS	PROVIDE 12' OF CLASS 5 GRAVEL DRAINAGE BEDDING UNDER THE GROUND SLEEVE.	
C:\Us VOLTA	COMPLETELY INSTALLALL CONDUIT RUNS AND BACKFILL DUCTBANKS BEFORE PULLING CABLE PULL A FLEXBLE MANDREL AND BURSH THROUGH FACH CONDUIT AFTER INSTALLATION. INSTALLA 3// DIMMETER THYLON PULL ROPE IN LAL SPARE CONDUTS.		
	 MEDILIN VOLTAGE CONDUCTORS SHALL BE PLUE DUSING DRECT CONNECTION OF PLULING EYES TO THE CONDUCTORS OF ACH CARLE AN THE CREDUIT OF BY INDIVIDUAL KELLENS GRES APPLIED TO EACH CARLE OF THE CREDUIT OVER THE MULLIATION WITH THE RES SHELDING RAMPUNCE USE OF RELEAS GRIPS OVER THE OUTER JACKET OF THE CONDUCTOR OR OVER THE SHELDING TAKED IS NOT PERMITTED. 	_	
	 INSTALL HANDHOLES AS REQUIRED TO MINIMIZE MAXIMUM ALLOWABLE CABLE TENSION PER CABLE MANUFACTURER WHEN PULLING CABLES. 		
MH 6	 SPLICES ARE NOT PERMITTED IN POWER OR CONTROL CONDUCTORS UNLESS INDICATED ON THE DRAWINGS OR APPROVED IN ADVANCE OF INSTALLATION BY ENGINEER AND OWNER. 		DATE: 07-18-2016 DRAWN BY: VB ENGINEER: AF
16 5:5	 WHERE CONDUCTORS OF DIFFERENT CROUTE PASS THROUGH THE SAME INAMOLE. HANDLOE OR PULLEDX, COVER THE CONDUCTORS OF EACH ORCUT WITH ARC-PROOF TAPE. MS SCOTCH 77 OR EQUIVACE, STRAL, HRAPPED LANE. LANE DIR ALCOMENTATION AND A CARDINAL READER HRAPPED CALSS 	A	APPROVED BY: AF PROJECT PHASE:
0/20	HIBER TAPE. 6. TERMINATE ALL CONTROL WIRING BETWEEN PIECES OF EQUIPMENT ON FIELD WIRING TERMINAL		30% DESIGN SCALE:
1/11	BOARDS. LABEL ALL CONTROL WIRES WITH TERMINAL BOARD AND TERMINAL NUMBER IDENTIFICATION AT BOTH ENDS.		NTS SHEET NO :
ted: 1			F-002
Ŀ.			

CITY OF EL PASO DE ROBLES "The Pass of the Oaks" Attachment 9

AFFIDAVIT

OF MAIL NOTICES

PLANNING COMMISSION/CITY COUNCIL PROJECT NOTICING

I, <u>Monica Hollenbeck</u>, employee of the City of El Paso de Robles, California, do hereby certify that the mail notices have been processed as required for Conditional Use Permit 16-004, on this 23rd day of November, 2016.

City of El Paso de Robles Community Development Department Planning Division

Signed: Monica C Hollenbeck

1000 SPRING STREET . PASO ROBLES, CALIFORNIA 93446 . www.prcity.com

CITY OF EL PASO DE ROBLES "The Pass of the Oaks"

Attachment 10

AFFIDAVIT

OF MAIL NOTICES

PLANNING COMMISSION/CITY COUNCIL PROJECT NOTICING

I, Monica Hollenbeck, employee of the City of El Paso de Robles, California, do hereby certify that the mail notices have been processed as required for Conditional Use Permit 16-005, on this 23rd day of November, 2016.

City of El Paso de Robles Community Development Department **Planning Division**

Signed: Monica C Hollouber Monica Hollenbeck

1000 SPRING STREET • PASO ROBLES, CALIFORNIA 93446 • www.prcity.com

UKC (1-5) 2016 City of Plano Rollins Community Development Dept.

Attachment

3825 South Higuera • Post Office Box 112 • San Luis Obispo, California 93406-0112 • (805) 781-7800

In The Superior Court of The State of California In and for the County of San Luis Obispo AFFIDAVIT OF PUBLICATION

AD # 2797410 CITY OF PASO ROBLES

STATE OF CALIFORNIA

SS.

County of San Luis Obispo

I am a citizen of the United States and a resident of the County aforesaid; 1 am over the age of eighteen and not interested in the above entitled matter; I am now, and at all times embraced in the publication herein mentioned was, the principal clerk of the printers and publishers of THE TRIBUNE, a newspaper of general Circulation, printed and published daily at the City of San Luis Obispo in the above named county and state; that notice at which the annexed clippings is a true copy, was published in the above-named newspaper and not in any supplement thereof - on the following dates to wit; DECEMBER 2, 2016 that said newspaper was duly and regularly ascertained and established a newspaper of general circulation by Decree entered in the Superior Court of San Luis Obispo County, State of California, on June 9, 1952, Case #19139 under the Government Code of the State of California.

I certify (or declare) under the penalty of perjury that the foregoing is true and correct.

Mue E. Maran

(Signature of Principal Clerk) DATED: DECEMBER 2, 2016 AD COST: \$186.34

NOTICE OF PUBLIC HEARING

NOTICE IS HEREBY GIVEN that the Planning Commission of the City of El Paso de Robias will hold a Public Hearing on Tuesday, December 13, 2016, at 6:30 p.m. at the City of El Paso de Robles, 1000 Spring Streat, Paso Robles, California, in the City Council Chambern, to consider the following projects:

Conditional Use Permit (CUP 16-004): A request filed by SunEdison LLC proposing to install a photovoltale system canopy atructure within the existing parking lot of Centennial Park located at 600 Nickerson Drive.

Conditional Use Permit (CUP 16-005): A request filed by SunEdison LLC proposing to install a photovoltaic system canopy structure within the existing parking lot of Sherwood Park located at 1860 Creston Road.

Both applications are Categorically Exempt from environmental raview under the State's Guidelines to Implement the California Environmental Quality Act (CEOA) per Section 21080.35 of the Public Resources Code.

The application and staff report may be reviewed at the Community Development Department, 1000 Spring Street, Paso Robles, California: Copies may be purchased for the cost of reproduction. The staff report is also available on the City's website starting the Friday before the hearing.

Written comments on the project may be malled to the Community Development Department, 1000 Spring Street, Paso Robles, CA 93446 or emailed to planning @ prcity.com, provided that the comments are received prior to the time of the public hearing. Oral comments may be made at the hearing. Should you have any questions regarding this application, please call Darcy Delgado at (805) 237-3970 or by email at ddelgado @prcity.com.

If you challenge the project in court, you may be limited to raising only those issues you or someone else raised at the public hearing described in this notice, or in writtern correspondence delivered to the Planning Commission at or prior to the public hearing.

Darcy Delgado Assistant Planner December 2, 2016 2797410